




Opinion **Dynamics**

AMEREN ILLINOIS COMPANY

2024 VOLTAGE OPTIMIZATION PROGRAM

IMPACT EVALUATION REPORT

FINAL
MARCH 28, 2025



CONTENTS

| | |
|--|----|
| 1. Executive Summary..... | 4 |
| 1.1 Background..... | 4 |
| 1.2 2024 Voltage Optimization Program Savings..... | 5 |
| 2. Overview of Voltage Optimization Program..... | 6 |
| 2.1 Background..... | 6 |
| 2.2 Program Description..... | 7 |
| 3. Voltage Optimization Evaluation Approach..... | 8 |
| 3.1 Evaluation Research Objectives..... | 8 |
| 3.2 Verified Impact Analysis Approach..... | 8 |
| 3.3 Sources and Mitigation of Error..... | 10 |
| 4. 2024 Voltage Optimization Program Verified Savings..... | 12 |
| 4.1 Annual Savings Summary..... | 12 |
| 4.2 Cumulative Persisting Annual Savings..... | 13 |
| 4.3 Verification of Continued Operations..... | 14 |
| 5. Conclusions and Recommendations..... | 15 |
| Appendix A. 2024 Voltage Optimization Circuit Summary..... | 16 |
| Appendix B. Detailed Impact Analysis Methodology..... | 22 |
| Appendix C. Cumulative Persisting Annual Savings..... | 39 |
| Appendix D. Verification of Continued Operations..... | 40 |

TABLES & FIGURES

| | |
|---|----|
| Table 1. 2024 VO Program Annual Energy and Peak Demand Savings..... | 5 |
| Table 2. 2024 VO Program CPAS and WAML..... | 5 |
| Table 3. AIC’s Original VO Implementation Plan and Savings Estimates..... | 7 |
| Table 4. 2024 VO Program Annual Energy and Peak Demand Savings..... | 12 |
| Table 5. Ex Ante and Verified Algorithmic Inputs and Associated Energy Savings..... | 13 |
| Table 6. Verified Algorithmic Inputs and Associated Demand Savings..... | 13 |
| Table 7 2024 VO Program CPAS and WAML..... | 13 |
| Table 8. 2024 Evaluated VO Circuits..... | 16 |
| Table 9. Summary of Data Cleaning Results for 2024 VO Energy Savings Impacts..... | 23 |
| Table 10. Verified Algorithmic Inputs and Associated Energy Savings by Circuit..... | 25 |

| | |
|--|----|
| Table 11. Summary of Data Cleaning Results for Peak Demand Savings..... | 30 |
| Table 12. Verified Algorithmic Inputs and Associated Peak Demand Savings by Circuit..... | 32 |
| Table 13. 2024 VO Program CPAS and WAML through 2039..... | 39 |
| Table 14. Total CPAS vs. Expected CPAS Per AIC’s Original VO Implementation Plan..... | 39 |
| Table 15. Sample of Circuits Evaluated in 2019, 2020, 2021, 2022, and 2023..... | 40 |
| Figure 1. Illustration of VO Effect on Voltage | 6 |

I. EXECUTIVE SUMMARY

This report presents the impact evaluation results from Ameren Illinois Company's (AIC) Voltage Optimization (VO) Program implemented in 2024. The objective of the 2024 impact evaluation was to determine energy and peak demand savings associated with the VO Program and verify the continued operation of voltage optimization for a sample of previously evaluated circuits.

I.1 BACKGROUND

VO is an energy efficiency technology that electric utilities implement at the distribution substation or circuit level. This technology optimizes voltage levels along distribution circuits to reduce electricity usage. AIC's VO Program employs a combination of hardware, software, and communications solutions that leverage VO technologies. The two primary VO technologies used are Volt-VAR Optimization (VVO) and Conservation Voltage Reduction (CVR). VVO improves the power factor to reduce line losses, and CVR reduces customer energy consumption by reducing line voltage. Once implemented, VO technologies are intended to operate 24 hours a day, every day of the year. This report discusses the investigation and analysis of circuits integrated with VO technology, and these will herein be referred to as "circuits."

Prior to the program launch, AIC identified multiple technology upgrades required to successfully deploy the VO Program and selected a pool of potential candidate circuits for VO deployment.¹ In 2017, AIC began installing VO hardware, software, and communications components on a subset of the selected circuits on a phased basis. As outlined in the AIC Voltage Optimization Plan,² AIC is only allowed to claim savings for circuits that are operational during a full calendar year. Program Year 2024 is the sixth full calendar year in which AIC is claiming energy savings.

The 2024 evaluation activities included estimating energy and peak demand savings for all 214 circuits that became operational in 2024 and verifying the continued operation of a sample of circuits previously evaluated in 2019, 2020, 2021, 2022, and 2023 (2, 13, 18, 19, and 20 sampled circuits, respectively).

¹ AIC staff used voltage level as the primary criteria for establishing the initial pool of potential candidate circuits and excluded circuits served by voltage levels > 20 kilovolts (kV) or that only serve customers exempt at the time of this determination (a customer whose highest 15-minute demand is \geq 10 MW). In addition, only circuits that were estimated to be cost-effective based on a TRC test were deemed eligible.

² Ameren Illinois Voltage Optimization Plan, filed in ICC Docket 18-0211 on January 25, 2018. Accessed at: <https://www.icc.illinois.gov/downloads/public/edocket/463457.pdf>.

1.2 2024 VOLTAGE OPTIMIZATION PROGRAM SAVINGS

1.2.1 ANNUAL SAVINGS

We estimated energy and peak demand savings for all 214 circuits that became operational in 2024. Overall, the 2024 VO Program achieved 77,169 MWh of verified net energy savings and 13.66 MW of verified net peak demand savings (Table 1).

Table 1. 2024 VO Program Annual Energy and Peak Demand Savings

| Metric | Energy Savings (MWh) | Peak Demand Savings (MW) | Gas Savings (Therms) |
|------------------------------------|----------------------|--------------------------|----------------------|
| Ex Ante Gross Savings ^a | 70,743 | N/A | N/A |
| Gross Realization Rate | 109% | N/A | N/A |
| Verified Gross Savings | 77,169 | 13.66 | N/A |
| NTGR | N/A | N/A | N/A |
| Verified Net Savings | 77,169 | 13.66 | N/A |

^a Ex ante energy savings sourced from AIC. Ex ante gross savings assume a 0.80 CVR factor and 3.2% voltage reduction across the 214 measured circuits. There are no ex ante demand savings estimates for this program.

1.2.2 CUMULATIVE PERSISTING ANNUAL SAVINGS

Table 2 summarizes cumulative persisting annual savings (CPAS) and the weighted average measure life (WAML) for the 2024 VO Program. The overall WAML for the VO Program is 15 years. For additional details about CPAS and WAML, please see Appendix C of this report.

Table 2. 2024 VO Program CPAS and WAML

| Measure | Measure Life | Annual Verified Gross Savings (MWh) | NTGR | CPAS – Verified Net Savings (MWh) | | | | | | | Lifetime Savings (MWh) |
|------------------------------------|--------------|-------------------------------------|------|-----------------------------------|--------|--------|--------|-----|--------|-----|------------------------|
| | | | | 2024 | 2025 | 2026 | 2027 | ... | 2030 | ... | |
| Voltage Optimization – 2024 Cohort | 15.0 | 77,169 | N/A | 77,169 | 77,169 | 77,169 | 77,169 | ... | 77,169 | ... | 1,157,529 |
| 2024 CPAS | | 77,169 | N/A | 77,169 | 77,169 | 77,169 | 77,169 | ... | 77,169 | ... | 1,157,529 |
| Expiring 2024 CPAS | | | | 0 | 0 | 0 | 0 | ... | 0 | ... | |
| Expired 2024 CPAS | | | | 0 | 0 | 0 | 0 | ... | 0 | ... | |
| WAML | 15.0 | | | | | | | | | | |


2. OVERVIEW OF VOLTAGE OPTIMIZATION PROGRAM

Illinois state law defines voltage optimization as an energy efficiency measure and allows AIC to make cost-effective voltage optimization investments as part of its energy efficiency portfolio.³

2.1 BACKGROUND

AIC defines VO as a combination of VVO and CVR, which are implemented first to reduce the reactive power flows on a circuit and then to lower the voltage in order to reduce end-use customer energy consumption and utility distribution system losses.⁴ VVO optimizes capacitor bank⁵ operations to improve power factor and reduce system losses.⁶ CVR utilizes voltage regulators, transformer load tap changers and capacitors to control and reduce end-user voltages, which, in turn, lowers customers' energy consumption. In other words, VVO and CVR technologies work together to reduce distribution line voltage by regulating voltage in the lower portion of the allowable range. Historically, utilities have regulated voltage in the upper portion of the range to avoid low voltage violations. However, AIC regulates voltage in the lower portion of the range, which does not compromise power quality. Most end uses use less energy at lower voltage, due to VO technologies. (Figure 1).

Figure 1. Illustration of VO Effect on Voltage



VO technologies can operate 24 hours a day, every day of the year. Energy savings are predominantly driven through end-use load reduction and, to a lesser extent, distribution line loss reductions. While AIC's VO Program was developed to provide energy savings, not peak demand savings, some associated demand reduction on some circuits is to be expected during the hours of operation of the system.

³ Specifically, 220 ILCS 5/8-103B(b-20).

⁴ Reactive power is measured in Volt-Amperes Reactive (VAR).

⁵ Capacitor banks are groupings of several capacitors and are used to store or condition electricity (e.g., by correcting power factor).

⁶ Power factor is the ratio of working power (kW) to apparent power (kVA). Higher power factors indicate higher efficiency.

2.2 PROGRAM DESCRIPTION

AIC developed the VO Program, described in the Ameren Illinois Voltage Optimization Plan (referred to as the Plan hereafter), to comply with Illinois state law and achieve energy savings supporting its energy efficiency portfolio goals.⁷ Per the Plan, AIC anticipates deploying VO on all circuits, which is estimated to be cost-effective by 2024. AIC initially planned to deploy VO on a total of 1,047 circuits by 2024.⁸ The program team has indicated that they now expect to deploy VO to more than 1,200 circuits by the end of 2024.⁹

Before the program launch, AIC identified multiple technology upgrades required to deploy VO. In 2017, AIC began installing VO hardware, software, and communications components on a phased basis on a subset of the eligible circuits using four different VO vendor solutions: Utilidata, DVI, OSI, and ABB Group.¹⁰ AIC staff used voltage level as the primary criteria for establishing the initial pool of candidate circuits and excluded circuits served by voltage levels >20 kilovolts (kV) and circuits that at the time served only customers exempt under Illinois state law (customers whose highest 15-minute demand is greater than or equal to 10 MW).¹¹

Table 3 provides AIC’s original implementation plan and savings estimates for the VO Program.

Table 3. AIC’s Original VO Implementation Plan and Savings Estimates

| Year Ending | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|---|------|-------|--------|---------|---------|---------|---------|---------|
| Estimated Cumulative Persisting Annual Savings (MWh) | 0 | 7,650 | 59,994 | 128,433 | 201,725 | 275,006 | 348,287 | 421,568 |
| % Annual Cumulative Persisting Savings | 0% | 0.03% | 0.21% | 0.46% | 0.72% | 0.98% | 1.25% | 1.50% |
| Estimated Incremental # of Circuits Deployed | 19 | 130 | 170 | 182 | 182 | 182 | 182 | 0 |
| Estimated Incremental Construction Cost (Capital Cost) | \$2M | \$14M | \$18M | \$19M | \$19M | \$19M | \$19M | \$0 |
| Estimated Incremental Total Investment Cost (Construction Capital, Construction O&M, Upfront Capital) | \$5M | \$17M | \$20M | \$20M | \$20M | \$20M | \$20M | \$0 |

Source: Ameren Illinois Voltage Optimization Plan

VO is a major part of AIC’s 2022–2025 energy efficiency plan. Per AIC’s most recent filing, VO was expected to yield 73,281 MWh in energy savings in 2024, about 17% of AIC’s total estimated 2024 portfolio energy savings goal.¹² In 2024, AIC completed the deployment of VO technology to 214 new circuits, which were then evaluated as part of the 2024 program year.

⁷ Ameren Illinois Voltage Optimization Plan, filed in ICC Docket 18-0211 on January 25, 2018. Accessed at:

<https://www.icc.illinois.gov/downloads/public/edocket/463457.pdf>

⁸ The number of circuits planned for VO deployment was determined based on a cost-effectiveness study using calculated assumptions, industry results, and past AIC VO pilot results. The actual number of circuits with VO could fluctuate based on deployment results. See Ameren Illinois Voltage Optimization Plan for details.

⁹ Interview with VO implementation staff of AIC on July 7, 2023.

¹⁰ AIC has now selected a primary vendor, and remaining circuit construction is proceeding with only one solution.

¹¹ Note that as a result of the Climate and Equitable Jobs Act, customers with >10MW demand are no longer automatically exempt.

¹² Appendix F to AIC’s 2022–2025 EE Plan. Accessed at:

<https://www.icc.illinois.gov/docket/P2021-0158/documents/322771/files/561827.pdf>

3. VOLTAGE OPTIMIZATION EVALUATION APPROACH

The 2024 VO evaluation approach was primarily governed by the Illinois Technical Reference Manual for Energy Efficiency (IL-TRM) Version 12.0, which prescribes the use of an algorithmic approach to estimating electric energy and peak demand savings from VO activities.¹³ In addition to the IL-TRM, we leveraged a previously agreed-upon methodology and approach to verifying the continued operation of previously installed circuits during 2024.¹⁴

In this report, we address the following key research questions:

- What are the estimated energy savings from VO?
- What are the estimated peak demand savings from VO?
- Did the 2, 13, 18, 19, and 20 sampled circuits from 2019, 2020, 2021, 2022, and 2023 deployment operate for over 90% of non-excludable hours in 2024?¹⁵

3.1 EVALUATION RESEARCH OBJECTIVES

The 2024 VO evaluation estimated annual energy savings and peak demand savings for the 214 operational circuits as of January 1, 2024.

3.2 VERIFIED IMPACT ANALYSIS APPROACH

3.2.1 ENERGY SAVINGS METHODOLOGY

The IL-TRM requires the use of an algorithmic approach to evaluate VO energy savings. The algorithmic approach combines deemed parameter values with measured reductions in voltage to calculate energy savings. The algorithm used for AIC's VO Program energy savings evaluation is shown in Equation 1.

Equation 1. AIC VO Energy Savings Algorithm

$$\text{Annual Energy Savings}_i = \text{Annual Energy Use}_{2014-2016,i} * CVR_f * \% \Delta V_i$$

Where:

- $\text{Annual Energy Use}_{2014-2016,i}$ = the average annual customer energy use for circuit i over the 2014–2016 timeframe, excluding exempt customers;
- CVR_f = conservation voltage reduction factor, defined as the percent change in energy usage divided by the percent change in voltage (deemed at 0.80 by the IL-TRM V12.0); and,

¹³ Illinois Statewide Technical Reference Manual for Energy Efficiency Version 12.0, Volume 4, Cross-Cutting Measures and Attachments, Measure 6.2.1. Accessed at:

https://www.ilsag.info/wp-content/uploads/IL-TRM_Effective_010124_v12.0_Vol_4_X-Cutting_Measures_and_Attach_09222023_FINAL.pdf

¹⁴ Ameren Illinois Company Voltage Optimization Verification and Exclusion Approach Memo, accessed at:

<https://www.ilsag.info/wp-content/uploads/AIC-2019-Voltage-Optimization-Operation-Verification-Memo-FINAL-2020-04-17.pdf>

¹⁵ Roughly 10 percent of the evaluated circuits, chosen randomly.

- $\% \Delta V_i$ = the percent change in voltage for circuit i resulting from VO implementation relative to the pre-period, estimated using a regression model to control for exogenous factors that may contribute to changes in voltage (e.g., weather).

3.2.2 PEAK DEMAND SAVINGS METHODOLOGY

Peak demand savings were also estimated using an algorithmic approach. The peak period is defined as 1:00 p.m.–5:00 p.m. (CDT) on non-holiday weekdays from June 1 to August 31.¹⁶ The algorithm used for AIC’s VO peak demand savings program evaluation is shown in Equation 2.

Equation 2. AIC VO Peak Demand Savings Algorithm

$$\text{Peak Demand Savings}_i = \text{Avg Peak Demand}_{2014-2016,i} * \text{CVR}_{f,PEAK} * \% \Delta V_{i,PEAK}$$

Where:

- $\text{Avg Peak Demand}_{2014-2016,i}$ = the average demand in the peak hour for circuit i over the 2014–2016 timeframe during the peak period adjusted by a calibration factor that captures the relationship between peak demand and average demand in the peak period, excluding >10 MW customers;
- $\text{CVR}_{f,PEAK}$ = the estimate of the peak conservation voltage reduction factor, defined as the percent change in energy usage divided by the percent change in voltage during the peak period (deemed at 0.68 by the IL-TRM V12.0); and,
- $\% \Delta V_{i,PEAK}$ = the percent change in voltage for circuit i resulting from VO implementation relative to the peak hours of the pre-period, using a regression model to control for exogenous factors that may contribute to changes in voltage (e.g., weather). Per the guidance in the IL-TRM, this is to be calculated in the same manner as energy savings but with the intention of measuring peak demand savings rather than total energy savings.

3.2.3 VERIFICATION OF CONTINUED OPERATION

The IL-TRM V12.0 deems VO savings for 15 years after completion of the initial evaluation of a circuit.¹⁷ Retroactive changes to deemed savings are not permitted.¹⁸ Therefore, in the Illinois evaluation framework, impact evaluation for VO does not require retroactive or ongoing verification.

Nevertheless, in 2020, Opinion Dynamics, AIC, and ICC staff agreed that ongoing verification of VO should be conducted for process purposes to provide information to all stakeholders as to the level of continued VO operation and, if needed, to provide context as to why VO may not have operated continuously. All parties agreed that Opinion Dynamics would conduct verification activities to assess the degree to which VO continued to operate in a sample of circuits deployed

¹⁶ Illinois Statewide Technical Reference Manual for Energy Efficiency Version 12.0, Volume 4, Cross-Cutting Measures and Attachments, Measure 6.2.1. Accessed at:

https://www.ilsag.info/wp-content/uploads/IL-TRM_Effective_010124_v12.0_Vol_4_X-Cutting_Measures_and_Attach_09222023_FINAL.pdf

¹⁷ Note that the IL-TRM V12.0 outlines a process through which the measure life for VO, including circuits that have already been evaluated and had savings claimed, can be “extended.” AIC and its evaluator will revisit past circuits at the expiration of their existing measure life, beginning in the 2034 program year.

¹⁸ Illinois Energy Efficiency Policy Manual Version 3.0, Section 11.2. Accessed at:

https://www.ilsag.info/wp-content/uploads/IL_EE_Policy_Manual_Version_3.0_Final_11-3-2023.pdf

and evaluated prior to the current evaluation period. An acceptable uptime threshold of operation was set to ensure that circuits operated over 90% of the time, barring non-operation due to excludable events.¹⁹

As part of the 2024 evaluation, Opinion Dynamics verified ongoing operation in circuits evaluated in 2019, 2020, 2021, 2022, and 2023. To determine whether these circuits operated at or over the target 90% uptime threshold during 2024, we conducted the following analytical activities:

- Selected a random sample of 2 of the 19 circuits evaluated in 2019, 13 of the 125 circuits evaluated in 2020, 18 of the 180 circuits evaluated in 2021, 19 of the 181 circuits evaluated in 2022, and 20 of the 194 circuits evaluated in 2023;
- Requested operation log summaries for the sample of circuits. Our variable of interest for this effort included the VO status (e.g., “On/Off”) at a circuit level for all hours throughout 2024;
- Removed excludable events;²⁰ and,
- Divided the total number of hours the status logs indicated that VO was ‘On’ by the total number of non-excludable hours in the year.

3.2.4 CONSIDERATION OF VOLTAGE OPTIMIZATION NET EFFECTS

Because AIC is the sole operator and “participant” in the VO Program, no adjustments to savings were made to reflect net effects (free ridership and spillover) that are often present for other, more traditional energy efficiency programs.

3.3 SOURCES AND MITIGATION OF ERROR

Because the evaluation team relied on regression models to estimate the change in voltage and peak demand, some uncertainty is to be expected in the model-produced estimates. Therefore, the team designed analyses to address the following types of errors:

- **Model Specification Error:** The most difficult type of modeling error in terms of bias and the ability to mitigate it is specification error. In this type of error, variables that determine model outcomes are excluded when they should not be, potentially producing biased estimates. We addressed this type of error by carefully examining the model diagnostics and goodness-of-fit statistics of the data variables.
- **Measurement Errors:** Specifying an incorrect time period (either VO “On” or VO “Off”) can lead to measurement error. We worked extensively with AIC to ensure that operations log data anomalies were discussed and addressed where possible. Measurement error can also come from variables such as weather data, which are commonly included in consumption analysis models. If an inefficient base temperature is chosen for calculating degree days or an incorrect climate zone weather station is chosen, the model results could be subject to measurement error. We mitigated this type of error by meticulously choosing the closest weather station for each circuit in the model to ensure the most accurate weather data were used in the model.
- **Multi-collinearity:** This type of modeling error can both bias and produce substantial variances in the results. We dealt with this type of error by using evaluation model diagnostics, though the models used in the impact analysis are unlikely to have problems with multi-collinearity.

¹⁹ Ameren Illinois Company Voltage Optimization Verification and Exclusion Approach Memo, accessed at:

<https://www.ilsag.info/wp-content/uploads/AIC-2019-Voltage-Optimization-Operation-Verification-Memo-FINAL-2020-04-17.pdf>

²⁰ For the rationale behind and definition of excludable events, please see the IL-TRM Voltage Optimization measure: Illinois Statewide Technical Reference Manual for Energy Efficiency Version 12.0, Volume 4 Cross-Cutting Measures and Attachments, Measure 6.2.1. Accessed at:

https://www.ilsag.info/wp-content/uploads/IL-TRM_Effective_010124_v12.0_Vol_4_X-Cutting_Measures_and_Attach_09222023_FINAL.pdf

- **Heteroskedasticity:** This type of modeling error can result in imprecise statistical inference due to variance changing across circuits with different consumption levels. We addressed this type of error by using robust standard errors. Most statistical packages offer a robust standard error option and make conservative assumptions when calculating errors, which also makes the model's significance tests conservative.

4. 2024 VOLTAGE OPTIMIZATION PROGRAM VERIFIED SAVINGS

In this section, we present the results of the impact evaluation of the 2024 VO Program. Additional details on the impact analysis methodology used for this evaluation are presented in Appendix B.

4.1 ANNUAL SAVINGS SUMMARY

The 2024 VO Program deployed the VO technology to 214 circuits, achieving 77,169 MWh of verified net energy savings and 13.66 MW of verified net peak demand savings. The year-end verified savings are within 0.3% of the interim report's forecasted savings of 76,940 MWh. Table 4 presents the 2024 VO Program annual energy and peak demand savings. Detailed results by circuit are available in Appendix B.

Table 4. 2024 VO Program Annual Energy and Peak Demand Savings

| Metric | Energy Savings (MWh) | Peak Demand Savings (MW) | Gas Savings (Therms) |
|------------------------------------|----------------------|--------------------------|----------------------|
| Ex Ante Gross Savings ^a | 70,743 | N/A | N/A |
| Gross Realization Rate | 109% | N/A | N/A |
| Verified Gross Savings | 77,169 | 13.66 | N/A |
| NTGR | N/A | N/A | N/A |
| Verified Net Savings | 77,169 | 13.66 | N/A |

^a Ex ante energy savings sourced from AIC. Ex ante gross savings assume 0.80 CVR factor and 3.2% voltage reduction across the 214 measured circuits. There are no ex ante demand savings estimates for this program.

Factors driving program performance include the following:

- The 2024 VO Program exceeded its ex ante gross energy savings due to larger estimated percent changes in voltage than assumed values (3.20% ex ante compared to 3.43% verified weighted average).
- Greater changes in voltage resulted in greater than expected energy savings, and the program achieved a gross realization rate of 109%.

4.1.1 DETAILED ENERGY SAVINGS

Savings were calculated using the annual energy savings algorithm, which uses the CVR factor (CVRf), the percent change in voltage resulting from VO implementation relative to the baseline, and average annual customer energy use over the 2014–2016 timeframe, excluding exempt customers. We used regression models to estimate the percent change in voltage for each circuit, applied that to the CVRf, and assumed the baseline of each circuit. Table 5 summarizes the energy savings results across all 214 circuits (see Appendix B for circuit-level percent change in voltage results).

Table 5. Ex Ante and Verified Algorithmic Inputs and Associated Energy Savings

| Metric | Annual Gross Energy Use (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|----------------------|-------------------------------|------|-----------------------------------|-----------------------------------|
| Ex Ante ^a | 2,763,403 | 0.80 | 3.20% | 70,743 |
| Verified | 2,763,403 | 0.80 | 3.49% ^a | 77,169 ^b |
| Realization Rate | 100% | 100% | 109% | 109% |

^a Weighted average percent change in voltage is obtained after weighing circuit-level voltage reductions in percentage terms by their 2014–2016 average yearly energy usage in MWh.

^b Application of Equation 1 to values in Table 5 does not produce 77,169 MWh savings due to the rounding of the Average Percent Change in Voltage value.

4.1.2 DETAILED PEAK DEMAND SAVINGS

Given the variability of load across circuits, we estimated peak demand savings using an individual regression analysis approach for each circuit. The percentage voltage reduction for each circuit was multiplied by the peak period CVRf of 0.68 (deemed) and the annual peak demand baseline value (measured in MW). The resulting peak demand savings were summed across circuits to determine the total peak demand reduction of 13.66 MW. The weighted average percent change in voltage during peak demand periods was 2.95%, as shown in Table 6. AIC does not report ex ante demand savings; therefore, no ex ante savings or realization rates are reported.

Table 6. Verified Algorithmic Inputs and Associated Demand Savings

| Metric | Peak Demand (MW) | CVRf | Average Percent Change in Peak Voltage | Peak Demand Savings (MW) |
|----------|------------------|------|--|--------------------------|
| Verified | 680.21 | 0.68 | 2.95% ^a | 13.66 |

^a Weighted average percent change in peak voltage is obtained after weighing feeder level voltage reductions in percentage terms by their 2014–2016 average yearly energy usage in MWh.

4.2 CUMULATIVE PERSISTING ANNUAL SAVINGS

Table 7 presents CPAS and WAML for the 2024 VO Program. The total verified gross savings for the Program are summarized, and CPAS in 2024–2027 and 2030 are presented. The WAML for the Program is 15 years.

Table 7 2024 VO Program CPAS and WAML

| Measure | Measure Life | Annual Verified Gross Savings (MWh) | NTGR | CPAS – Verified Net Savings (MWh) | | | | | | | Lifetime Savings (MWh) |
|------------------------------------|--------------|-------------------------------------|------|-----------------------------------|--------|--------|--------|-----|--------|-----|------------------------|
| | | | | 2024 | 2025 | 2026 | 2027 | ... | 2030 | ... | |
| Voltage Optimization – 2024 Cohort | 15.0 | 77,169 | N/A | 77,169 | 77,169 | 77,169 | 77,169 | ... | 77,169 | ... | 1,157,529 |
| 2024 CPAS | | 77,169 | N/A | 77,169 | 77,169 | 77,169 | 77,169 | ... | 77,169 | ... | 1,157,529 |
| Expiring 2024 CPAS | | | | 0 | 0 | 0 | 0 | ... | 0 | ... | |
| Expired 2024 CPAS | | | | 0 | 0 | 0 | 0 | ... | 0 | ... | |
| WAML | 15.0 | | | | | | | | | | |

4.3 VERIFICATION OF CONTINUED OPERATIONS

As discussed in Section 3.2.3, we analyzed status logs for a randomly selected sample of previously implemented circuits to verify continued VO operation. In 2024, we sampled 2 of the 19 circuits evaluated in 2019, 13 of the 125 circuits evaluated in 2020, 18 of the 180 circuits evaluated in 2021, 19 of the 181 circuits evaluated in 2022, and 20 of the 194 circuits evaluated in 2023. Per the terms of the verification agreement, detailed further in Section 3.2.2, we set a threshold of operation of 90% of non-excludable hours. Our analysis found that all sampled circuits were “On” for more than 90% of non-excludable hours in 2024.

More information on the verification approach can be found in Appendix D.

5. CONCLUSIONS AND RECOMMENDATIONS

Based on the results of this evaluation, we offer the following key findings and recommendations for AIC's VO Program moving forward:

- **Key Finding #1:** The VO Program continues to provide substantial energy savings to the AIC portfolio and exceeds AIC's initial expectations for savings achieved.
- **Key Finding #2:** The average percent change in voltage due to VO was 3.49%, higher than the planning value of 3.20%. There is substantial variation across circuits in percent change in voltage (0.08%–5.41%). For 154 of the 214 evaluated circuits, the percent change in voltage was estimated to be larger than the planning value of 3.20%.
 - **Recommendation:** Consider further updates to planning values to reflect the percent change in voltage derived from evaluated values. AIC updated the planning value from 3% to 3.20% in 2022, which better aligns with evaluation findings to date, but the planning value continues to significantly understate verified results. Updating the planning value could also support a more accurate assessment of the ex ante cost-effectiveness for each circuit screened for inclusion in the program.
- **Key Finding #3:** The evaluation team found that all of the 72 circuits sampled from the 2019-2023 evaluation cohorts were "On" for more than the 90% threshold of non-excludable hours in 2024. Specially, the uptime ranges from 93.20% to 99.80% of non-excludable hours, with an average of 99.45%. This indicates that VO is being appropriately maintained and operated and continues to suggest that the approach of prospectively deeming VO savings is likely to closely represent actual achieved energy savings over time.
- **Key Finding #4:** The evaluation team developed and presented forecasts of year-end savings with its first and second interim impact analysis of 2024. The year-end verified savings are within 0.3% of the interim report forecasted savings of 76,940 MWh.

APPENDIX A. 2024 VOLTAGE OPTIMIZATION CIRCUIT SUMMARY

Table 8 presents detailed characteristics for VO circuits evaluated in 2024. It includes the circuit name and substation for each circuit, as well as various circuit characteristics that may affect voltage reductions. Since AIC prioritized low-income customers as part of its VO deployment, we also note the number of low-income customers estimated to be served by each circuit evaluated in 2024 when data are available.

Table 8. 2024 Evaluated VO Circuits

| Circuit | Substation | Line Length (Miles) | % Res. | % Com. | % Large C&I | Voltage Level | Low-Income Customers |
|---------|----------------|---------------------|--------|--------|-------------|---------------|----------------------|
| 301051 | MITCHELL-12 | 6.1 | 79% | 20% | 0% | 7.20 | 3 |
| 301052 | MITCHELL-12 | 8.6 | 93% | 6% | 0% | 7.20 | 7 |
| 301053 | MITCHELL-12 | 12.3 | 26% | 46% | 29% | 7.20 | 1 |
| 326168 | SPRING 1 | 4.4 | 73% | 25% | 2% | 4.16 | 6 |
| 326169 | SPRING 1 | 2.2 | 48% | 52% | 0% | 4.16 | 1 |
| 326170 | SPRING 1 | 2.9 | 0% | 83% | 17% | 4.00 | N/A |
| 350103 | ARROW WOOD 1 | 14.2 | 94% | 6% | 0% | 4.16 | 1 |
| 350104 | ARROW WOOD 1 | 10.4 | 98% | 3% | 0% | 4.00 | N/A |
| A32001 | WALLACE 1 | 3.2 | 0% | 100% | 0% | 13.20 | N/A |
| A32002 | WALLACE 1 | 5.1 | 0% | 91% | 9% | 13.20 | N/A |
| A32003 | WALLACE 1 | 7.0 | 90% | 9% | 1% | 7.62 | 13 |
| A49001 | FARMDALE 1 | 14.0 | 87% | 13% | 0% | 7.62 | 12 |
| A49002 | FARMDALE 1 | 12.9 | 90% | 10% | 0% | 7.62 | 3 |
| A49003 | FARMDALE 1 | 32.2 | 98% | 2% | 0% | 7.62 | 11 |
| A50001 | FLINT 1 | 19.9 | 85% | 15% | 0% | 7.20 | 20 |
| A50002 | FLINT 1 | 14.8 | 40% | 58% | 2% | 12.00 | N/A |
| A73002 | WHEELER 1 | 57.7 | 83% | 17% | 0% | 7.62 | 1 |
| A85001 | SAND PRAIRIE 1 | 101.6 | 79% | 21% | 0% | 7.62 | 25 |
| A91001 | ALLEN 1 | 37.1 | 95% | 5% | 0% | 7.62 | 2 |
| A91002 | ALLEN 1 | 48.4 | 90% | 9% | 0% | 7.62 | 1 |
| B08002 | JUNCTION 1 | 3.8 | 81% | 18% | 1% | 7.62 | 11 |
| B08003 | JUNCTION 2 | 8.8 | 87% | 13% | 0% | 13.20 | N/A |
| B08004 | JUNCTION 2 | 8.4 | 81% | 19% | 0% | 7.62 | 5 |
| B62001 | METAMORA 1 | 79.1 | 88% | 11% | 0% | 7.62 | 10 |
| B62002 | METAMORA 2 | 29.2 | 95% | 5% | 0% | 7.62 | 3 |
| B62004 | METAMORA 1 | 42.7 | 91% | 9% | 1% | 7.62 | 9 |
| B84001 | BUSH 2 | 4.2 | 33% | 65% | 1% | 12.00 | N/A |
| B84002 | BUSH 2 | 32.6 | 95% | 5% | 0% | 7.20 | 23 |
| B84003 | BUSH 1 | 11.1 | 89% | 11% | 0% | 12.00 | N/A |
| B84004 | BUSH 1 | 3.8 | 72% | 27% | 1% | 7.20 | 5 |
| B84005 | BUSH 1 | 19.0 | 89% | 11% | 0% | 12.00 | N/A |
| B84006 | BUSH 1 | 20.2 | 88% | 12% | 0% | 7.20 | 5 |
| C10002 | ATLANTA 1 | 34.7 | 82% | 18% | 0% | 7.20 | 6 |
| C15002 | RIVERTON 1 | 33.3 | 94% | 6% | 0% | 12.00 | N/A |

| Circuit | Substation | Line Length (Miles) | % Res. | % Com. | % Large C&I | Voltage Level | Low-Income Customers |
|---------|-----------------------------|---------------------|--------|--------|-------------|---------------|----------------------|
| C50001 | HEYWORTH 1 | 56.6 | 91% | 8% | 0% | 7.20 | 5 |
| C50002 | HEYWORTH 1 | 6.9 | 84% | 16% | 0% | 12.00 | 1 |
| C50003 | HEYWORTH 1 | 37.9 | 74% | 26% | 0% | 12.00 | 1 |
| C65001 | WILLIAMSVILLE 1 | 33.6 | 88% | 12% | 0% | 7.20 | 2 |
| D35002 | HENRY 1 | 23.0 | 87% | 13% | 0% | 7.20 | 10 |
| D41001 | ALTA 1 | 32.9 | 99% | 1% | 0% | 7.62 | 2 |
| D41002 | ALTA 1 | 23.1 | 93% | 7% | 0% | 7.62 | 2 |
| D41003 | ALTA 1 | 53.0 | 95% | 5% | 0% | 13.20 | N/A |
| D41004 | ALTA 1 | 2.7 | 59% | 41% | 0% | 13.20 | N/A |
| D69001 | RADNOR 1 | 14.3 | 50% | 47% | 3% | 7.62 | 2 |
| D69002 | RADNOR 1 | 12.2 | 77% | 23% | 0% | 13.20 | N/A |
| D69003 | RADNOR 1 | 12.8 | 98% | 2% | 0% | 7.62 | 3 |
| D69004 | RADNOR 1 | 18.2 | 91% | 8% | 0% | 7.62 | 4 |
| D69005 | RADNOR 1 | 15.8 | 89% | 10% | 0% | 7.62 | 6 |
| D69006 | RADNOR 2 | 67.9 | 84% | 15% | 1% | 7.62 | 4 |
| D69007 | RADNOR 2 | 6.2 | 81% | 19% | 0% | 13.20 | 1 |
| D69008 | RADNOR 2 | 38.4 | 97% | 3% | 0% | 7.62 | 40 |
| D69009 | RADNOR 2 | 32.7 | 87% | 13% | 0% | 13.20 | N/A |
| F03003 | ROCHESTER OAK ST 1 | 87.3 | 89% | 11% | 1% | 7.20 | 3 |
| F03004 | ROCHESTER OAK ST 2 | 20.9 | 93% | 7% | 0% | 7.20 | 2 |
| H01190 | WEST ILLIOPOLIS 2 | 67.1 | 83% | 17% | 0% | 12.00 | 6 |
| H01192 | WEST ILLIOPOLIS 1 | 43.5 | 84% | 16% | 0% | 12.00 | N/A |
| H01194 | WEST ILLIOPOLIS 1 | 45.9 | 88% | 12% | 0% | 7.20 | 9 |
| HE3303 | SHILOH TAMARACK 1 | 11.5 | 96% | 4% | 0% | 7.20 | 3 |
| HE3304 | SHILOH TAMARACK 1 | 7.4 | 94% | 5% | 0% | 7.20 | 4 |
| HE3305 | SHILOH TAMARACK 1 | 5.8 | 0% | 100% | 0% | 12.00 | N/A |
| J05138 | ALEDO 2 | 15.8 | 92% | 8% | 0% | 12.00 | 4 |
| J05139 | ALEDO 3 | 17.9 | 60% | 35% | 5% | 7.20 | 1 |
| J07135 | ALPHA 1 | 131.8 | 81% | 19% | 1% | 7.20 | 2 |
| J12166 | ARGENTA 1 | 42.0 | 92% | 7% | 0% | 7.20 | 3 |
| J13108 | ARPEE JUNCTION 1 | 65.2 | 83% | 16% | 0% | 7.20 | 17 |
| J18267 | AVISTON 1 | 45.5 | 89% | 11% | 0% | 7.20 | 10 |
| J18268 | AVISTON 1 | 52.3 | 90% | 10% | 0% | 7.20 | 3 |
| J47175 | BLOOMINGTON EMPIRE ST 2 | 3.1 | 85% | 15% | 0% | 12.00 | 4 |
| J47176 | BLOOMINGTON EMPIRE ST 2 | 8.0 | 93% | 6% | 0% | 7.20 | 2 |
| J47178 | BLOOMINGTON EMPIRE ST 1 | 13.8 | 86% | 14% | 0% | 7.20 | 24 |
| J47179 | BLOOMINGTON EMPIRE ST 1 | 2.7 | 0% | 100% | 0% | 12.00 | N/A |
| J68401 | BLOOMINGTON WASHINGTON ST 1 | 10.6 | 77% | 22% | 1% | 7.20 | 8 |
| J68402 | BLOOMINGTON WASHINGTON ST 1 | 12.6 | 53% | 44% | 3% | 7.20 | 2 |
| J82116 | BELLEVILLE 17TH ST 3 | 3.5 | 89% | 11% | 0% | 4.00 | 5 |
| J83137 | BELLEVILLE 44TH ST 1 | 10.0 | 93% | 7% | 0% | 12.00 | 12 |
| J83139 | BELLEVILLE 44TH ST 1 | 4.8 | 81% | 19% | 0% | 12.00 | 13 |

| Circuit | Substation | Line Length (Miles) | % Res. | % Com. | % Large C&I | Voltage Level | Low-Income Customers |
|---------|------------------------------|---------------------|--------|--------|-------------|---------------|----------------------|
| J86108 | BELLEVILLE 88TH ST 1 | 13.0 | 96% | 4% | 0% | 7.20 | 12 |
| J86118 | BELLEVILLE 88TH ST 1 | 9.3 | 90% | 10% | 0% | 12.00 | 12 |
| K36151 | CLINTON MONROE ST 2 | 32.6 | 83% | 16% | 1% | 7.20 | 6 |
| K36252 | CLINTON MONROE ST 1 | 0.7 | 61% | 39% | 0% | 4.00 | 1 |
| K57211 | COLUMBIA 2 | 23.3 | 94% | 6% | 0% | 7.20 | 1 |
| K57212 | COLUMBIA 2 | 14.0 | 83% | 16% | 0% | 7.20 | 6 |
| K58210 | COLUMBIA PALMER CREEK 1 | 23.8 | 85% | 14% | 1% | 7.20 | 2 |
| K58213 | COLUMBIA PALMER CREEK 1 | 40.0 | 90% | 10% | 0% | 12.00 | N/A |
| K71810 | CHAMPAIGN KIRBY AVE 1 | 10.0 | 99% | 1% | 0% | 7.20 | 3 |
| K71811 | CHAMPAIGN KIRBY AVE 1 | 11.0 | 97% | 3% | 0% | 7.20 | 15 |
| K71812 | CHAMPAIGN KIRBY AVE 1 | 35.6 | 94% | 6% | 0% | 7.20 | 19 |
| K71822 | CHAMPAIGN KIRBY AVE 2 | 10.7 | 99% | 1% | 0% | 7.20 | 17 |
| K78351 | CHAMPAIGN SOUTHWEST CAMPUS 2 | 5.3 | 2% | 98% | 0% | 12.00 | N/A |
| K78352 | CHAMPAIGN SOUTHWEST CAMPUS 2 | 9.4 | 89% | 11% | 0% | 7.20 | 4 |
| K82202 | DANVERS 1 | 39.9 | 88% | 11% | 0% | 7.20 | 7 |
| L08225 | DECATUR LEAFLAND AVE 1 | 7.5 | 91% | 9% | 0% | 4.00 | 16 |
| L11241 | DECATUR MICHIGAN AVE 1 | 4.9 | 91% | 8% | 0% | 4.16 | 6 |
| L11244 | DECATUR MICHIGAN AVE 2 | 5.3 | 96% | 4% | 0% | 4.00 | 13 |
| L14231 | DECATUR NORTH 21ST ST 1 | 7.2 | 59% | 40% | 1% | 4.16 | 1 |
| L50217 | DUPO 1 | 7.5 | 87% | 13% | 0% | 7.20 | 2 |
| L71170 | DANVILLE EASTGATE 1 | 6.6 | 0% | 96% | 4% | 12.00 | N/A |
| L73154 | DANVILLE FRANKLIN ST 1 | 4.3 | 76% | 24% | 0% | 4.00 | 10 |
| L73155 | DANVILLE FRANKLIN ST 2 | 3.5 | 64% | 36% | 0% | 4.00 | 9 |
| L73156 | DANVILLE FRANKLIN ST 1 | 2.1 | 82% | 18% | 0% | 4.00 | 8 |
| L73184 | DANVILLE FRANKLIN ST 2 | 3.2 | 63% | 37% | 0% | 4.00 | 1 |
| L73185 | DANVILLE FRANKLIN ST 3 | 3.6 | 66% | 34% | 0% | 12.00 | 5 |
| M05360 | EDWARDSVILLE SECOND STREET 2 | 46.4 | 93% | 7% | 0% | 7.20 | 10 |
| M05361 | EDWARDSVILLE SECOND STREET 2 | 19.8 | 92% | 8% | 0% | 7.20 | 6 |
| M05362 | EDWARDSVILLE SECOND STREET 3 | 8.3 | 73% | 26% | 1% | 7.20 | 4 |
| M54314 | GRANITE CITY 22ND STREET 1 | 5.9 | 93% | 7% | 0% | 4.00 | 20 |
| M54316 | GRANITE CITY 22ND STREET 2 | 4.4 | 94% | 6% | 0% | 4.00 | 22 |
| M54317 | GRANITE CITY 22ND STREET 2 | 2.5 | 89% | 11% | 0% | 4.00 | 6 |
| M73329 | GRANITE CITY KATE STREET 1 | 3.1 | 95% | 5% | 0% | 4.00 | 8 |
| M73330 | GRANITE CITY KATE STREET 1 | 3.1 | 97% | 3% | 0% | 4.00 | 17 |
| N14879 | GREENVILLE ROUTE 40 1 | 13.1 | 73% | 26% | 2% | 7.20 | 3 |
| N14880 | GREENVILLE ROUTE 40 1 | 16.2 | 74% | 26% | 0% | 12.00 | 9 |
| N73121 | LAKEVIEW-DANVILLE 1 | 6.1 | 93% | 7% | 0% | 4.00 | 16 |
| P53341 | MONTICELLO ROUTE 105 1 | 28.5 | 89% | 11% | 0% | 7.20 | 4 |
| P77235 | NEW ATHENS 1 | 13.1 | 92% | 8% | 0% | 7.20 | 4 |
| P77237 | NEW ATHENS 2 | 41.4 | 82% | 18% | 0% | 12.00 | N/A |
| Q10702 | NORTH GRANITE CITY 1 | 11.6 | 38% | 54% | 7% | 7.20 | 1 |

| Circuit | Substation | Line Length (Miles) | % Res. | % Com. | % Large C&I | Voltage Level | Low-Income Customers |
|---------|---------------------------|---------------------|--------|--------|-------------|---------------|----------------------|
| Q18243 | O FALLON 1 | 4.8 | 76% | 23% | 0% | 7.20 | 1 |
| Q18244 | O FALLON 2 | 8.8 | 90% | 10% | 0% | 7.20 | 2 |
| Q18245 | O FALLON 1 | 12.4 | 92% | 7% | 0% | 7.20 | 6 |
| Q21292 | O FALLON PORTER ROAD 4 | 7.9 | 71% | 27% | 1% | 7.20 | 4 |
| Q21293 | O FALLON PORTER ROAD 4 | 27.1 | 96% | 4% | 0% | 12.00 | N/A |
| Q21294 | O FALLON PORTER ROAD 3 | 16.6 | 79% | 21% | 0% | 12.00 | N/A |
| Q21321 | O FALLON PORTER ROAD 3 | 24.3 | 89% | 11% | 0% | 7.20 | 8 |
| Q21322 | O FALLON PORTER ROAD 4 | 7.7 | 86% | 13% | 1% | 7.20 | 1 |
| Q21423 | O FALLON PORTER ROAD 3 | 27.7 | 90% | 10% | 0% | 7.20 | 3 |
| Q24310 | OFALLON TROY ROAD 1 | 23.6 | 99% | 1% | 0% | 12.00 | N/A |
| Q24311 | OFALLON TROY ROAD 1 | 31.3 | 97% | 3% | 0% | 12.00 | N/A |
| Q24312 | OFALLON TROY ROAD 2 | 31.4 | 98% | 2% | 0% | 7.20 | 1 |
| Q67948 | PINCKNEYVILLE ROUTE 154 1 | 37.8 | 90% | 9% | 0% | 7.20 | 3 |
| R01152 | SOUTH BLOOMINGTON 4 | 17.7 | 90% | 10% | 1% | 7.20 | 11 |
| R10941 | SPARTA 2 | 3.7 | 88% | 12% | 0% | 12.00 | N/A |
| R10943 | SPARTA 1 | 21.0 | 90% | 10% | 0% | 7.20 | 10 |
| R50910 | TROY GROVE 1 | 78.7 | 86% | 13% | 1% | 7.20 | 3 |
| R58921 | URBANA FIVE POINTS 2 | 5.3 | 80% | 20% | 0% | 4.16 | 7 |
| R66472 | URBANA WASHINGTON ST 1 | 8.2 | 96% | 4% | 0% | 12.00 | 45 |
| R71286 | VALMEYER RT. 156 1 | 52.0 | 94% | 5% | 0% | 7.20 | 2 |
| R93350 | WANDA 2 | 29.6 | 82% | 16% | 2% | 7.20 | 10 |
| R93351 | WANDA 2 | 22.0 | 92% | 8% | 0% | 7.20 | 4 |
| R95520 | WEDRON 1 | 94.8 | 89% | 11% | 0% | 7.20 | 5 |
| S01511 | ANNA 2 | 6.7 | 92% | 7% | 1% | 7.20 | 5 |
| S01521 | ANNA 2 | 11.4 | 75% | 25% | 0% | 12.00 | 5 |
| S01558 | ANNA 1 | 2.0 | 76% | 24% | 0% | 4.00 | 2 |
| S13548 | CARBONDALE, ILL ST 1 | 1.5 | 90% | 8% | 2% | 4.16 | 3 |
| S13550 | CARBONDALE, ILL ST 1 | 1.3 | 30% | 69% | 1% | 4.00 | N/A |
| S20554 | CARRIER MILLS 1 | 12.8 | 83% | 17% | 0% | 12.00 | 12 |
| S47537 | HERRIN 1 | 10.5 | 98% | 2% | 0% | 7.20 | 7 |
| S47575 | HERRIN 3 | 12.0 | 87% | 12% | 1% | 7.20 | 10 |
| S47576 | HERRIN 1 | 29.8 | 88% | 12% | 0% | 7.20 | 8 |
| S47586 | HERRIN 2 | 2.1 | 68% | 32% | 1% | 4.16 | 1 |
| U07001 | AUBURN | 4.5 | 84% | 16% | 0% | 4.00 | 3 |
| U07002 | AUBURN | 4.4 | 87% | 13% | 0% | 4.00 | 3 |
| U09540 | AUBURN, W 2 | 5.3 | 29% | 71% | 0% | 12.00 | N/A |
| U09557 | AUBURN, W 3 | 14.8 | 90% | 10% | 0% | 7.20 | 3 |
| U09569 | AUBURN, W 3 | 10.9 | 96% | 4% | 0% | 12.00 | 2 |
| U57560 | GIRARD 1 | 9.6 | 87% | 12% | 1% | 7.20 | 13 |
| U57561 | GIRARD 1 | 9.9 | 89% | 11% | 0% | 12.00 | 11 |
| U60518 | GRAFTON JCT 1 | 35.2 | 78% | 21% | 1% | 7.20 | 5 |
| U64518 | GRIGGSVILLE, N 1 | 10.5 | 83% | 17% | 0% | 12.00 | 1 |

| Circuit | Substation | Line Length (Miles) | % Res. | % Com. | % Large C&I | Voltage Level | Low-Income Customers |
|---------|------------------------|---------------------|--------|--------|-------------|---------------|----------------------|
| U64521 | GRIGGSVILLE, N 1 | 26.4 | 81% | 18% | 1% | 7.20 | 13 |
| U80003 | JERSEYVILLE 3 | 3.1 | 79% | 21% | 0% | 4.00 | 9 |
| U80564 | JERSEYVILLE 2 | 21.7 | 65% | 35% | 1% | 7.20 | 20 |
| V04537 | MEREDOSIA-SWITCHYARD 1 | 2.5 | 0% | 64% | 36% | 12.00 | N/A |
| V21500 | PETERSBURG 1 | 32.3 | 92% | 8% | 0% | 7.20 | 10 |
| V21548 | PETERSBURG 1 | 38.0 | 81% | 19% | 0% | 12.00 | 1 |
| V38001 | QUINCY,21&BDWY 1 | 1.9 | 93% | 6% | 0% | 4.00 | 1 |
| V38003 | QUINCY,21&BDWY 1 | 1.5 | 85% | 15% | 0% | 4.00 | 3 |
| V40549 | QUINCY,24&CHERRY 1 | 11.8 | 95% | 5% | 0% | 12.00 | 1 |
| V41527 | QUINCY,28&ADAMS 1 | 7.3 | 97% | 3% | 0% | 12.00 | 11 |
| V43543 | QUINCY,30&TURNER 1 | 1.5 | 0% | 91% | 9% | 12.00 | N/A |
| V43565 | QUINCY,30&TURNER 1 | 1.2 | 17% | 67% | 17% | 12.00 | N/A |
| V47001 | QUINCY,BLESS HOSP 1 | 1.9 | 75% | 23% | 2% | 4.16 | 1 |
| V55524 | QUINCY,SOYBEAN 1 | 4.5 | 50% | 50% | 0% | 12.00 | N/A |
| V89523 | MT. STERLING,SOUTH 1 | 0.9 | 67% | 33% | 0% | 12.00 | N/A |
| V92542 | HAMILTON 12KV 2 | 32.4 | 87% | 12% | 0% | 7.20 | 10 |
| V92543 | HAMILTON 12KV 1 | 14.0 | 89% | 10% | 0% | 7.20 | 6 |
| V92555 | HAMILTON 12KV 1 | 12.3 | 89% | 11% | 0% | 7.20 | 9 |
| X19561 | BISMARCK 1 | 51.0 | 89% | 11% | 0% | 7.20 | 8 |
| X35500 | CHARLESTON,S (EIU) 1 | 2.5 | 89% | 11% | 0% | 12.00 | 2 |
| X35564 | CHARLESTON,S (EIU) 1 | 2.3 | 94% | 6% | 0% | 12.00 | 1 |
| X64002 | FAIRBURY 2 | 2.1 | 75% | 25% | 0% | 4.00 | 3 |
| X64003 | FAIRBURY 2 | 4.0 | 82% | 18% | 0% | 4.00 | 3 |
| X64503 | FAIRBURY 1 | 11.1 | 84% | 16% | 0% | 7.20 | 3 |
| X66581 | FARINA 1 | 5.7 | 76% | 24% | 0% | 12.00 | 3 |
| X82576 | HOOPESTON 2 | 12.5 | 87% | 13% | 0% | 12.00 | 11 |
| X82585 | HOOPESTON 2 | 6.2 | 96% | 4% | 0% | 12.00 | 4 |
| X83533 | HOOPESTON,S 1 | 14.7 | 91% | 9% | 0% | 12.00 | 6 |
| X96001 | LAWRENCEVILLE,S 4 | 3.2 | 85% | 15% | 0% | 4.00 | 8 |
| X96002 | LAWRENCEVILLE,S 4 | 1.9 | 86% | 14% | 0% | 4.00 | 3 |
| X96523 | LAWRENCEVILLE,S 3 | 11.2 | 91% | 9% | 0% | 12.00 | 24 |
| Y11555 | MATTOON,NW 1 | 13.2 | 90% | 10% | 0% | 12.00 | 19 |
| Y11557 | MATTOON,NW 2 | 1.3 | 33% | 0% | 67% | 12.00 | N/A |
| Y31589 | NOBLE 1 | 17.6 | 80% | 20% | 0% | 7.20 | 14 |
| Y31591 | NOBLE 1 | 13.5 | 71% | 28% | 1% | 12.00 | N/A |
| Y32571 | NOKOMIS 1 | 6.9 | 93% | 7% | 0% | 12.00 | 9 |
| Y32572 | NOKOMIS 1 | 5.9 | 72% | 28% | 0% | 12.00 | 3 |
| Y36541 | OLNEY,N 3 | 28.9 | 84% | 15% | 0% | 7.20 | 17 |
| Y54001 | PARIS,W 2 | 2.0 | 85% | 15% | 0% | 4.00 | 3 |
| Y54560 | PARIS,W 1 | 17.0 | 55% | 43% | 1% | 12.00 | N/A |
| Y54587 | PARIS,W 1 | 8.3 | 86% | 13% | 1% | 7.20 | 10 |
| Y54591 | PARIS,W 1 | 8.4 | 92% | 8% | 0% | 12.00 | 17 |

| Circuit | Substation | Line Length (Miles) | % Res. | % Com. | % Large C&I | Voltage Level | Low-Income Customers |
|---------|-----------------------|---------------------|--------|--------|-------------|---------------|----------------------|
| Y66556 | ROBINSON,W 1 | 7.5 | 78% | 21% | 0% | 7.20 | 6 |
| Y69553 | ST ELMO 1 | 10.4 | 78% | 22% | 0% | 12.00 | 5 |
| Y69565 | ST ELMO 1 | 8.1 | 83% | 17% | 0% | 12.00 | 5 |
| Y86593 | STOY 1 | 11.3 | 79% | 19% | 2% | 7.20 | 1 |
| Y86595 | STOY 1 | 17.0 | 83% | 17% | 0% | 7.20 | 4 |
| Y98518 | TUSCOLA,E 2 | 13.3 | 45% | 53% | 2% | 7.20 | 1 |
| Y98561 | TUSCOLA,E 2 | 11.5 | 93% | 6% | 0% | 7.20 | 3 |
| Z06538 | WATSEKA,E 2 | 7.9 | 79% | 20% | 2% | 7.20 | 4 |
| Z08509 | WENONAH 1 | 34.2 | 85% | 15% | 0% | 7.20 | 13 |
| Z11536 | WINDSOR 1 | 18.0 | 87% | 13% | 0% | 7.20 | 11 |
| Z19532 | ROBINSON COR CTR 1 | 1.9 | 45% | 55% | 0% | 12.00 | N/A |
| Z33511 | ASSUMPTION,EAST 1 | 0.2 | 0% | 0% | 100% | 12.00 | N/A |
| Z51556 | LAWRENCEVILLE, EAST 1 | 0.8 | 0% | 0% | 100% | 12.00 | N/A |

Note: N/A indicates that low-income data were not available.

APPENDIX B. DETAILED IMPACT ANALYSIS METHODOLOGY

DATA INGESTION AND REVIEW

Opinion Dynamics used the following data to perform the energy and peak demand savings evaluation: (1) advanced metering infrastructure (AMI) data extracts; (2) VO status and operations logs; (3) circuit characteristics; and (4) hourly weather data.

- **AMI data extracts.** AIC provided Opinion Dynamics with AMI data containing hourly demand (kWh), instantaneous voltage, and average instantaneous voltage at four different base voltages. AMI data are preferred for all evaluations in Illinois, and consumption is measured at the customer meter rather than the circuit level. Because there may be over 1,000 AMI meters on a given circuit, AIC provided average normalized voltage and kWh data. For a given circuit, the AMI data reflects normalized voltage based on the voltage class (e.g., 120V, 240V, 480V) where each AMI meter was located on the circuit.
- **System operations log.** This log contains the VO “On” and “Off” schedules, as well as information on critical system operation events that could cause data anomalies, such as outages. AIC provided this log with a summary tab containing VO status events (VO “On” and VO “Off”), timestamps for the events, and notes on the cause of the event. Within the system operations log, the evaluation team flagged certain time frames as excludable, adhering to guidance in the IL-TRM V12.0.
- **Circuit characteristics.** AIC provided Opinion Dynamics with a number of datasets with descriptive circuit characteristic information, including data presented in Appendix A, as well as baseline usage information.
- **Hourly weather data.** The evaluation team sourced weather data from the National Oceanic and Atmospheric Administration’s (NOAA) National Centers for Environmental Information, which were mapped to circuits using GPS coordinates. We then calculated the cooling and heating degree hours, using base temperatures of 75°F and 65°F, respectively, to generate the weather parameters used in modeling.

ENERGY SAVINGS

DATA CLEANING

To support the 2024 impact evaluation, we cleaned the provided data to meet analytical needs. 2024 VO data were provided by AIC incrementally throughout the year to support interim impact analyses. As such, we incrementally aggregated the VO data provided before we took further data-cleaning steps. During this aggregation, we took two steps to prepare data:

- **Remove perfectly duplicated observations:** Observations with perfectly duplicated values across all variables (e.g., perfect overlaps between data files) were flagged and removed from the analysis.
- **Aggregate remaining duplicate observations:** After removing perfect duplicates, a small number of observations remained with duplicate timestamps by circuit but different voltage data. In this case, we averaged observations to arrive at a dataset with a unique set of timestamps by circuit. This affected 0.02% of records.

Once the data were aggregated, we conducted the following data-cleaning steps prior to modeling:

- **Remove time periods without weather data:** As previously noted, we downloaded weather data from NOAA. We used circuit longitude and latitude to find the weather station closest to each circuit’s location. We removed the

corresponding time periods from the analysis for instances where weather data for a particular weather station was not recorded.

- **Remove negative and zero values:** Negative and zero values in kV and MW data were flagged and removed from use in the analysis.
- **Examine outliers:** Outliers were screened on a circuit-by-circuit basis. Exploration of the outliers showed that all outliers were within a reasonable range to be included in the analysis.
- **Flag excludable time periods:** In some circumstances, it is best practice or required to disable VO to support system changes, growth, outages, and maintenance, both planned and unplanned. AIC has indicated that a subset of VO events should be excluded in this analysis. In 2020, Opinion Dynamics, ICC Staff, and stakeholders agreed on specific VO events that could be considered excludable and memorialized them in a memo.²¹ VO events that were approved for exclusion were those for which (1) there was a circuit outage for any reason; (2) the circuit was under repair or maintenance, causing VO to be disabled; (3) VO was disabled due to any necessary switching event; (4) the circuit had experienced a failure in information or communication technology; and (5) any event was flagged for the worldwide pandemic or outages ordered by civil authorities. This information has now been memorialized in IL-TRM V12.0.
- **Remove “On” events in pre-period:** To construct a pre-period, “On” events were flagged and removed from the 2023 dataset.

Table 9 provides a summary of the second stage of data cleaning for this analysis. Results include all 214 circuits within the analysis. The primary driver for removing observations were occurrences when VO was turned “Off” for an excludable event (1.4% of total observations), followed by time periods without weather data (1.3% of total observations). Overall, after data cleaning activity, 2.7% of observations were dropped. It should be noted that no circuits were removed from the energy savings analysis due to data insufficiency.

Table 9. Summary of Data Cleaning Results for 2024 VO Energy Savings Impacts

| Cleaning Steps | Circuits | Remaining Observations | # Dropped Observations | % Remaining |
|-----------------------------------|------------|------------------------|------------------------|--------------|
| Initial Count | 214 | 3,722,688 | N/A | 100.0% |
| Aggregate Duplicates | 214 | 3,722,088 | 600 | 100.0% |
| Time Periods Without Weather Data | 214 | 3,674,369 | 47,719 | 98.7% |
| kV Less Than or Equal to 0 | 214 | 3,674,369 | 0 | 98.7% |
| On in Pre-Period | 214 | 3,674,369 | 0 | 98.7% |
| Excludable Time Periods | 214 | 3,620,717 | 53,652 | 97.3% |
| Final | 214 | 3,620,717 | 101,971 | 97.3% |

MODELING PERCENT CHANGE IN VOLTAGE FOR DEMAND SAVINGS

The evaluation team removed VO “On” periods in 2023 to develop a pre-period baseline for this evaluation. As a result, the baseline includes VO “Off” periods only. The post-period of interest is 2024 when all circuits are active. The post-period consists of largely “On” periods and non-excludable “Off” periods. The evaluation team used this structure to fit individual models on each circuit.

²¹ Ameren Illinois Company Voltage Optimization Verification and Exclusion Approach Memo, accessed at: <https://www.ilsag.info/wp-content/uploads/AIC-2019-Voltage-Optimization-Operation-Verification-Memo-FINAL-2020-04-17.pdf>

To estimate changes in voltage, we used a regression model described in Equation 3.

Equation 3. Voltage Reduction Model

$$kV_{it} = a_i + \beta_{1i}Post_{it} + \beta_{2i}CDH_{it} + \beta_{3i}HDH_{it} + \beta_{4i}Weekend_t + \beta_{5i}Post_{it} * CDH_{it} + \beta_{6i}Post_{it} * HDH_{it} + \beta_{7i}Post_{it} * Weekend_t + \varepsilon_{it}$$

Where:

- kV_{it} = Kilovolts for circuit i at time t
- a_i = Model intercept of circuit i
- β_x = Regression coefficients for circuit i
- $Post_{it}$ = Indicator variable for circuit i at time t for the time relative to VO deployment where the circuit is in the post-period ($Post_{it} = 1$) or in the pre-period ($Post_{it} = 0$)
- CDH_{it} = The number of cooling degree-hours at time t corresponding to circuit i
- HDH_{it} = The number of heating degree-hours at time t corresponding to circuit i
- $Weekend_t$ = Indicator variable for weekend ($Weekend_t = 1$) or weekday ($Weekend_t = 0$)
- ε_{it} = Error term

CALCULATING ANNUAL ENERGY SAVINGS

The IL-TRM V12.0 prescribes an algorithmic approach to evaluating VO energy savings. The algorithmic approach combines deemed parameter values with measured savings in voltage to calculate energy savings using Equation 4. Since we apply the estimated change in voltage to the circuit-level annual usage, the results are effectively annualized for the entire year.

Equation 4. AIC VO Energy Savings Algorithm

$$Annual\ Energy\ Savings_i = Annual\ Energy\ Use_{2014-2016,i} * CVR_f * \% \Delta V_i$$

Where:

- $Annual\ Energy\ Use_{2014-2016,i}$ = the average annual customer energy use for circuit i over the 2014–2016 timeframe, excluding exempt customers;
- CVR_f = conservation voltage reduction factor, defined as the percent change in energy usage divided by the percent change in voltage (deemed at 0.80 by the IL-TRM V12.0); and,
- $\% \Delta V_i$ = the percent change in voltage for circuit i resulting from VO implementation relative to the pre-period, estimated using a regression model to control for exogenous factors that may contribute to changes in voltage (e.g., weather).

DETAILED CIRCUIT RESULTS: ANNUAL ENERGY SAVINGS

Table 10 provides each algorithmic input by circuit as well as the total estimated savings per circuit that can be attributed to the VO Program. For 154 of the 214 circuits, the percent change in voltage was estimated to be larger than the planned value of 3.2%. The overall average percent change in voltage was 3.49%.

Table 10. Verified Algorithmic Inputs and Associated Energy Savings by Circuit

| Circuit | Annual Gross Energy Use 2014–2016 (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|---------|---|------|-----------------------------------|-----------------------------------|
| 301051 | 6,524 | 0.80 | 2.78% | 145 |
| 301052 | 10,288 | 0.80 | 2.79% | 230 |
| 301053 | 40,449 | 0.80 | 2.83% | 916 |
| 326168 | 15,909 | 0.80 | 0.63% | 80 |
| 326169 | 7,131 | 0.80 | 1.50% | 86 |
| 326170 | 17,542 | 0.80 | 1.85% | 259 |
| 350103 | 11,186 | 0.80 | 1.21% | 109 |
| 350104 | 10,270 | 0.80 | 1.36% | 112 |
| A32001 | 8,814 | 0.80 | 2.64% | 186 |
| A32002 | 24,750 | 0.80 | 2.64% | 523 |
| A32003 | 10,900 | 0.80 | 2.92% | 255 |
| A49001 | 19,555 | 0.80 | 3.43% | 536 |
| A49002 | 10,439 | 0.80 | 2.97% | 248 |
| A49003 | 21,234 | 0.80 | 4.58% | 778 |
| A50001 | 22,706 | 0.80 | 0.80% | 146 |
| A50002 | 22,219 | 0.80 | 1.29% | 230 |
| A73002 | 21,448 | 0.80 | 3.62% | 621 |
| A85001 | 22,391 | 0.80 | 2.51% | 449 |
| A91001 | 19,005 | 0.80 | 4.58% | 696 |
| A91002 | 17,826 | 0.80 | 4.18% | 597 |
| B08002 | 24,983 | 0.80 | 4.25% | 849 |
| B08003 | 6,988 | 0.80 | 4.52% | 253 |
| B08004 | 12,639 | 0.80 | 3.95% | 400 |
| B62001 | 30,333 | 0.80 | 3.71% | 900 |
| B62002 | 12,516 | 0.80 | 3.22% | 322 |
| B62004 | 16,252 | 0.80 | 4.52% | 587 |
| B84001 | 12,032 | 0.80 | 3.70% | 356 |
| B84002 | 24,967 | 0.80 | 2.60% | 519 |
| B84003 | 9,416 | 0.80 | 3.52% | 265 |
| B84004 | 33,263 | 0.80 | 1.73% | 459 |
| B84005 | 17,974 | 0.80 | 1.96% | 281 |
| B84006 | 14,822 | 0.80 | 0.90% | 106 |
| C10002 | 10,611 | 0.80 | 2.39% | 203 |
| C15002 | 11,493 | 0.80 | 3.62% | 333 |
| C50001 | 18,729 | 0.80 | 3.22% | 482 |

| Circuit | Annual Gross Energy Use 2014-2016 (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|---------|---|------|-----------------------------------|-----------------------------------|
| C50002 | 6,468 | 0.80 | 4.08% | 211 |
| C50003 | 4,392 | 0.80 | 3.39% | 119 |
| C65001 | 13,562 | 0.80 | 0.08% | 9 |
| D35002 | 14,186 | 0.80 | 3.01% | 341 |
| D41001 | 16,864 | 0.80 | 4.79% | 646 |
| D41002 | 15,380 | 0.80 | 3.92% | 483 |
| D41003 | 8,119 | 0.80 | 4.03% | 262 |
| D41004 | 6,351 | 0.80 | 3.51% | 178 |
| D69001 | 33,222 | 0.80 | 2.74% | 729 |
| D69002 | 28,640 | 0.80 | 2.38% | 545 |
| D69003 | 11,328 | 0.80 | 3.10% | 281 |
| D69004 | 25,025 | 0.80 | 3.30% | 660 |
| D69005 | 20,494 | 0.80 | 3.31% | 543 |
| D69006 | 26,408 | 0.80 | 1.70% | 359 |
| D69007 | 3,919 | 0.80 | 1.68% | 53 |
| D69008 | 24,298 | 0.80 | 1.43% | 278 |
| D69009 | 24,582 | 0.80 | 1.60% | 316 |
| F03003 | 29,761 | 0.80 | 3.44% | 819 |
| F03004 | 9,983 | 0.80 | 1.88% | 151 |
| H01190 | 12,901 | 0.80 | 3.86% | 398 |
| H01192 | 6,089 | 0.80 | 0.55% | 27 |
| H01194 | 13,824 | 0.80 | 4.54% | 502 |
| HE3303 | 9,081 | 0.80 | 3.72% | 270 |
| HE3304 | 9,415 | 0.80 | 5.20% | 392 |
| HE3305 | 4,907 | 0.80 | 2.09% | 82 |
| J05138 | 7,044 | 0.80 | 4.06% | 229 |
| J05139 | 18,120 | 0.80 | 3.08% | 446 |
| J07135 | 21,766 | 0.80 | 3.15% | 548 |
| J12166 | 15,246 | 0.80 | 4.44% | 541 |
| J13108 | 13,871 | 0.80 | 3.77% | 419 |
| J18267 | 19,546 | 0.80 | 3.85% | 602 |
| J18268 | 17,978 | 0.80 | 3.05% | 438 |
| J47175 | 6,945 | 0.80 | 1.75% | 97 |
| J47176 | 10,022 | 0.80 | 4.57% | 366 |
| J47178 | 26,152 | 0.80 | 2.83% | 592 |
| J47179 | 14,910 | 0.80 | 4.88% | 582 |
| J68401 | 30,377 | 0.80 | 2.72% | 660 |
| J68402 | 12,838 | 0.80 | 4.41% | 453 |
| J82116 | 5,029 | 0.80 | 5.12% | 206 |
| J83137 | 9,892 | 0.80 | 4.23% | 335 |
| J83139 | 9,797 | 0.80 | 4.78% | 374 |
| J86108 | 12,076 | 0.80 | 4.55% | 439 |
| J86118 | 9,415 | 0.80 | 4.28% | 322 |

| Circuit | Annual Gross Energy Use 2014–2016 (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|---------|---|------|-----------------------------------|-----------------------------------|
| K36151 | 22,531 | 0.80 | 2.76% | 497 |
| K36252 | 2,828 | 0.80 | 4.10% | 93 |
| K57211 | 18,741 | 0.80 | 4.99% | 748 |
| K57212 | 17,856 | 0.80 | 4.52% | 646 |
| K58210 | 27,937 | 0.80 | 4.25% | 950 |
| K58213 | 13,577 | 0.80 | 4.37% | 475 |
| K71810 | 7,094 | 0.80 | 4.95% | 281 |
| K71811 | 13,084 | 0.80 | 4.88% | 510 |
| K71812 | 31,077 | 0.80 | 4.60% | 1,144 |
| K71822 | 9,937 | 0.80 | 5.05% | 401 |
| K78351 | 26,787 | 0.80 | 3.94% | 844 |
| K78352 | 16,292 | 0.80 | 4.72% | 615 |
| K82202 | 13,814 | 0.80 | 1.79% | 198 |
| L08225 | 6,896 | 0.80 | 3.92% | 216 |
| L11241 | 19,617 | 0.80 | 4.77% | 749 |
| L11244 | 6,239 | 0.80 | 4.45% | 222 |
| L14231 | 15,694 | 0.80 | 3.24% | 407 |
| L50217 | 9,942 | 0.80 | 4.02% | 319 |
| L71170 | 16,642 | 0.80 | 3.48% | 463 |
| L73154 | 7,159 | 0.80 | 3.66% | 209 |
| L73155 | 6,196 | 0.80 | 4.22% | 209 |
| L73156 | 6,262 | 0.80 | 4.72% | 236 |
| L73184 | 2,832 | 0.80 | 4.38% | 99 |
| L73185 | 7,384 | 0.80 | 3.15% | 186 |
| M05360 | 19,413 | 0.80 | 4.15% | 645 |
| M05361 | 17,765 | 0.80 | 4.17% | 592 |
| M05362 | 23,619 | 0.80 | 3.45% | 652 |
| M54314 | 5,667 | 0.80 | 4.71% | 213 |
| M54316 | 4,864 | 0.80 | 4.33% | 169 |
| M54317 | 6,717 | 0.80 | 4.11% | 221 |
| M73329 | 6,755 | 0.80 | 4.13% | 223 |
| M73330 | 5,656 | 0.80 | 4.56% | 206 |
| N14879 | 11,928 | 0.80 | 4.50% | 430 |
| N14880 | 8,793 | 0.80 | 3.69% | 260 |
| N73121 | 5,847 | 0.80 | 3.52% | 165 |
| P53341 | 13,860 | 0.80 | 2.89% | 320 |
| P77235 | 10,242 | 0.80 | 4.27% | 349 |
| P77237 | 8,448 | 0.80 | 4.66% | 315 |
| Q10702 | 23,931 | 0.80 | 4.57% | 875 |
| Q18243 | 10,522 | 0.80 | 3.27% | 276 |
| Q18244 | 15,060 | 0.80 | 4.77% | 574 |
| Q18245 | 15,395 | 0.80 | 4.73% | 582 |
| Q21292 | 24,022 | 0.80 | 4.44% | 852 |

| Circuit | Annual Gross Energy Use 2014-2016 (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|---------|---|------|-----------------------------------|-----------------------------------|
| Q21293 | 16,032 | 0.80 | 4.77% | 612 |
| Q21294 | 25,478 | 0.80 | 4.44% | 905 |
| Q21321 | 17,868 | 0.80 | 4.33% | 619 |
| Q21322 | 18,234 | 0.80 | 2.69% | 392 |
| Q21423 | 18,684 | 0.80 | 4.70% | 703 |
| Q24310 | 13,225 | 0.80 | 5.27% | 558 |
| Q24311 | 12,660 | 0.80 | 5.12% | 518 |
| Q24312 | 12,890 | 0.80 | 4.95% | 510 |
| Q67948 | 13,951 | 0.80 | 4.81% | 537 |
| R01152 | 13,960 | 0.80 | 3.99% | 446 |
| R10941 | 2,323 | 0.80 | 4.50% | 84 |
| R10943 | 9,361 | 0.80 | 4.25% | 318 |
| R50910 | 19,573 | 0.80 | 3.28% | 513 |
| R58921 | 8,414 | 0.80 | 3.47% | 234 |
| R66472 | 9,054 | 0.80 | 4.84% | 351 |
| R71286 | 11,014 | 0.80 | 4.44% | 391 |
| R93350 | 21,677 | 0.80 | 4.02% | 697 |
| R93351 | 12,498 | 0.80 | 4.82% | 482 |
| R95520 | 11,357 | 0.80 | 3.23% | 293 |
| S01511 | 8,797 | 0.80 | 4.21% | 297 |
| S01521 | 4,495 | 0.80 | 3.76% | 135 |
| S01558 | 2,844 | 0.80 | 5.01% | 114 |
| S13548 | 12,453 | 0.80 | 3.03% | 302 |
| S13550 | 5,433 | 0.80 | 5.41% | 235 |
| S20554 | 8,353 | 0.80 | 3.66% | 244 |
| S47537 | 9,425 | 0.80 | 4.09% | 309 |
| S47575 | 14,792 | 0.80 | 3.97% | 470 |
| S47576 | 12,520 | 0.80 | 2.11% | 211 |
| S47586 | 10,189 | 0.80 | 4.45% | 363 |
| U07001 | 4,766 | 0.80 | 4.34% | 165 |
| U07002 | 5,734 | 0.80 | 3.94% | 181 |
| U09540 | 11,399 | 0.80 | 4.86% | 443 |
| U09557 | 14,636 | 0.80 | 4.05% | 474 |
| U09569 | 6,006 | 0.80 | 4.23% | 203 |
| U57560 | 11,868 | 0.80 | 3.56% | 338 |
| U57561 | 6,954 | 0.80 | 3.86% | 215 |
| U60518 | 14,373 | 0.80 | 2.74% | 314 |
| U64518 | 3,474 | 0.80 | 4.57% | 127 |
| U64521 | 13,453 | 0.80 | 4.97% | 535 |
| U80003 | 5,355 | 0.80 | 3.73% | 160 |
| U80564 | 17,379 | 0.80 | 4.27% | 594 |
| V04537 | 11,219 | 0.80 | 3.27% | 293 |
| V21500 | 13,028 | 0.80 | 3.51% | 366 |

| Circuit | Annual Gross Energy Use 2014-2016 (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|---------|---|------|-----------------------------------|-----------------------------------|
| V21548 | 5,345 | 0.80 | 5.02% | 215 |
| V38001 | 5,757 | 0.80 | 4.95% | 228 |
| V38003 | 2,923 | 0.80 | 4.36% | 102 |
| V40549 | 6,884 | 0.80 | 3.08% | 170 |
| V41527 | 8,250 | 0.80 | 4.58% | 302 |
| V43543 | 8,273 | 0.80 | 1.75% | 116 |
| V43565 | 20,282 | 0.80 | 0.71% | 116 |
| V47001 | 11,914 | 0.80 | 4.31% | 411 |
| V55524 | 7,107 | 0.80 | 4.06% | 231 |
| V89523 | 8,363 | 0.80 | 3.52% | 235 |
| V92542 | 11,735 | 0.80 | 2.78% | 261 |
| V92543 | 13,921 | 0.80 | 3.56% | 397 |
| V92555 | 13,484 | 0.80 | 3.23% | 348 |
| X19561 | 15,584 | 0.80 | 3.26% | 407 |
| X35500 | 3,703 | 0.80 | 4.10% | 121 |
| X35564 | 5,356 | 0.80 | 3.97% | 170 |
| X64002 | 3,105 | 0.80 | 3.57% | 89 |
| X64003 | 4,717 | 0.80 | 4.81% | 181 |
| X64503 | 9,684 | 0.80 | 3.89% | 301 |
| X66581 | 5,725 | 0.80 | 4.60% | 211 |
| X82576 | 5,829 | 0.80 | 3.99% | 186 |
| X82585 | 6,329 | 0.80 | 4.02% | 204 |
| X83533 | 8,587 | 0.80 | 4.82% | 331 |
| X96001 | 5,755 | 0.80 | 3.37% | 155 |
| X96002 | 3,270 | 0.80 | 4.58% | 120 |
| X96523 | 6,577 | 0.80 | 3.20% | 168 |
| Y11555 | 9,467 | 0.80 | 3.67% | 278 |
| Y11557 | 18,784 | 0.80 | 3.36% | 505 |
| Y31589 | 11,243 | 0.80 | 1.31% | 118 |
| Y31591 | 3,343 | 0.80 | 3.93% | 105 |
| Y32571 | 5,285 | 0.80 | 2.74% | 116 |
| Y32572 | 4,460 | 0.80 | 2.74% | 98 |
| Y36541 | 12,020 | 0.80 | 4.46% | 429 |
| Y54001 | 2,936 | 0.80 | 3.82% | 90 |
| Y54560 | 17,735 | 0.80 | 4.29% | 608 |
| Y54587 | 18,145 | 0.80 | 3.74% | 543 |
| Y54591 | 6,460 | 0.80 | 3.38% | 175 |
| Y66556 | 9,559 | 0.80 | 3.69% | 282 |
| Y69553 | 4,761 | 0.80 | 3.93% | 150 |
| Y69565 | 6,048 | 0.80 | 2.99% | 145 |
| Y86593 | 12,977 | 0.80 | 2.26% | 235 |
| Y86595 | 13,957 | 0.80 | 1.58% | 176 |
| Y98518 | 13,718 | 0.80 | 4.38% | 480 |

| Circuit | Annual Gross Energy Use 2014–2016 (MWh) | CVRf | Average Percent Change in Voltage | Annual Gross Energy Savings (MWh) |
|---------|---|------|-----------------------------------|-----------------------------------|
| Y98561 | 9,047 | 0.80 | 4.13% | 299 |
| Z06538 | 13,455 | 0.80 | 3.56% | 383 |
| Z08509 | 12,565 | 0.80 | 2.07% | 208 |
| Z11536 | 8,829 | 0.80 | 2.44% | 172 |
| Z19532 | 10,476 | 0.80 | 3.86% | 323 |
| Z33511 | 18,053 | 0.80 | 2.88% | 415 |
| Z51556 | 11,684 | 0.80 | 3.77% | 352 |

PEAK DEMAND ENERGY SAVINGS

DATA CLEANING

Data cleaning for the peak demand analysis included all steps undertaken for the energy savings model, plus the following additional cleaning steps:

- **Peak Period Data Only:** The VO peak demand model includes only observations during the peak period, defined as the hours of 1:00 p.m.–5:00 p.m. on non-holiday weekdays between June and August.
- **Less than 20 Days in Peak Period:** Circuits with less than 20 days in the peak period were removed from the analysis. No feeders were affected by this step.
- **Missing Peak Period:** Circuits missing the 2023 or 2024 peak period were removed from the analysis. No feeders were affected by this step.

Table 11 provides a summary of the data cleaning results for this analysis. Interim impact analysis 2 dataset, covering January through August, contains the entirety of the VO peak period as defined above. Starting with the January to August dataset, we removed all non-peak days. This step resulted in the removal of 78.5% of the data. The remainder of the data cleaning steps outlined below reduced the total number of observations by about 18 percentage points.

Table 11. Summary of Data Cleaning Results for Peak Demand Savings

| Cleaning Step | Circuits | Remaining Observations | # Dropped Observations | % Remaining |
|----------------------------------|------------|------------------------|------------------------|-------------|
| Initial Count | 214 | 3,037,680 ^a | 0 | N/A |
| Remove Non-Peak Days | 214 | 654,589 | 2,383,091 | 21.5% |
| Less than 20 Days in Peak Period | 214 | 654,589 | 0 | 21.5% |
| Missing Peak Period | 214 | 654,589 | 0 | 21.5% |
| Peak Hours | 214 | 109,296 | 545,293 | 3.6% |
| Final | 214 | 109,296 | 2,928,384 | 3.6% |

^a Interim impact analysis 2 dataset, covering January through August, contains the entirety of the VO peak period. We start peak period demand savings analysis using the January to August dataset. As such, the initial count in this table is less than the initial count in Table 9 that starts with the full year dataset.

MODELING PERCENT CHANGE IN VOLTAGE FOR DEMAND SAVINGS

To develop a baseline, the evaluation team used the 2023 and 2024 peak period subsets of the cleaned data. The peak period is defined as 1:00 p.m.–5:00 p.m. on non-holiday weekdays from June 1 to August 31. As with the energy savings model, the demand savings model uses 2023 as the pre-period and 2024 as the post-period. To estimate changes in voltage, we used a regression model described in Equation 5.

Equation 5. Voltage Reduction Model

$$kV_{it} = \alpha_i + \beta_{1i}Post_{it} + \beta_{2i}CDH_{it} + \beta_{3i}Post_{it} * CDH_{it} + \varepsilon_{it}$$

Where:

- kV_{it} = Kilovolts for circuit i at time t
- α_i = Model intercept for circuit i
- β_{xi} = Regression coefficients for circuit i
- $Post_{it}$ = Indicator variable for circuit i at time t for the time relative to VO deployment where the circuit is in the post-period ($Post_{it} = 1$) or in the pre-period ($Post_{it} = 0$)
- CDH_{it} = The number of cooling degree-hours at time t corresponding to circuit i
- ε_{it} = Error term

CALCULATING PEAK DEMAND ENERGY SAVINGS

VO peak demand savings are also estimated with an algorithmic approach using Equation 6.

Equation 6. AIC VO Peak Demand Savings Algorithm

$$Peak\ Demand\ Savings_i = Avg\ Peak\ Demand_{2014-2016,i} * CVR_{f,PEAK} * \% \Delta V_{i,PEAK}$$

Where:

- $Avg\ Peak\ Demand_{2014-2016,i}$ = the average demand in the peak hour for circuit i over the 2014–2016 timeframe during the peak period adjusted by a calibration factor that captures the relationship between peak demand and average demand in the peak period, excluding >10 MW customers;
- $CVR_{f,PEAK}$ = the estimate of the peak conservation voltage reduction factor, defined as the percent change in energy usage divided by the percent change in voltage during the peak period (deemed at 0.68 by the IL-TRM V12.0); and,
- $\% \Delta V_{i,PEAK}$ = the percent change in voltage for circuit i resulting from VO implementation relative to the peak hours of the pre-period, using a regression model to control for exogenous factors that may contribute to changes in voltage (e.g., weather). Per the guidance in the IL-TRM, this is to be calculated in the same manner as energy savings but to measure peak demand savings rather than total energy savings.

DETAILED CIRCUIT RESULTS: PEAK DEMAND ENERGY SAVINGS

Table 12 provides each algorithmic input by circuit and the total estimated savings per circuit that can be attributed to the VO Program. The overall average percent change in voltage was 2.95%.

Table 12. Verified Algorithmic Inputs and Associated Peak Demand Savings by Circuit

| Circuit | Annual Peak Demand 2014–2016 (MW) | CVR _{f,PEAK} | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|-----------------------|--|----------------------------|
| 301051 | 1.61 | 0.68 | 1.05% | 0.01 |
| 301052 | 2.52 | 0.68 | 1.00% | 0.02 |
| 301053 | 7.23 | 0.68 | 1.08% | 0.05 |
| 326168 | 3.76 | 0.68 | 0.62% | 0.02 |
| 326169 | 1.80 | 0.68 | 1.12% | 0.01 |
| 326170 | 2.85 | 0.68 | 1.32% | 0.03 |
| 350103 | 2.85 | 0.68 | -0.10% | 0.00 |
| 350104 | 2.75 | 0.68 | 0.08% | 0.00 |
| A32001 | 2.06 | 0.68 | 1.87% | 0.03 |
| A32002 | 5.52 | 0.68 | 1.92% | 0.07 |
| A32003 | 2.40 | 0.68 | 2.92% | 0.05 |
| A49001 | 5.62 | 0.68 | 2.34% | 0.09 |
| A49002 | 2.19 | 0.68 | 2.75% | 0.04 |
| A49003 | 6.89 | 0.68 | 3.89% | 0.18 |
| A50001 | 6.27 | 0.68 | 0.11% | 0.00 |
| A50002 | 5.20 | 0.68 | 0.99% | 0.04 |
| A73002 | 5.02 | 0.68 | 2.54% | 0.09 |
| A85001 | 6.67 | 0.68 | 1.13% | 0.05 |
| A91001 | 6.78 | 0.68 | 3.73% | 0.17 |
| A91002 | 5.20 | 0.68 | 3.42% | 0.12 |
| B08002 | 4.32 | 0.68 | 3.72% | 0.11 |
| B08003 | 2.79 | 0.68 | 4.13% | 0.08 |
| B08004 | 3.60 | 0.68 | 3.02% | 0.07 |
| B62001 | 1.82 | 0.68 | 3.01% | 0.04 |
| B62002 | 3.22 | 0.68 | 2.38% | 0.05 |
| B62004 | 4.24 | 0.68 | 3.61% | 0.10 |
| B84001 | 2.68 | 0.68 | 3.21% | 0.06 |
| B84002 | 7.07 | 0.68 | 0.36% | 0.02 |
| B84003 | 1.51 | 0.68 | 2.07% | 0.02 |
| B84004 | 2.90 | 0.68 | 0.08% | 0.00 |
| B84005 | 4.48 | 0.68 | 0.38% | 0.01 |
| B84006 | 3.27 | 0.68 | -0.29% | -0.01 |
| C10002 | 2.54 | 0.68 | 1.19% | 0.02 |
| C15002 | 3.53 | 0.68 | 3.76% | 0.09 |
| C50001 | 5.79 | 0.68 | 1.75% | 0.07 |
| C50002 | 1.38 | 0.68 | 3.08% | 0.03 |

| Circuit | Annual Peak Demand 2014–2016 (MW) | $CVR_{f,PEAK}$ | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|----------------|--|----------------------------|
| C50003 | 2.00 | 0.68 | 2.37% | 0.03 |
| C65001 | 3.67 | 0.68 | -0.71% | -0.02 |
| D35002 | 3.17 | 0.68 | 1.35% | 0.03 |
| D41001 | 2.08 | 0.68 | 3.99% | 0.06 |
| D41002 | 4.35 | 0.68 | 2.60% | 0.08 |
| D41003 | 2.28 | 0.68 | 2.85% | 0.04 |
| D41004 | 0.99 | 0.68 | 2.25% | 0.02 |
| D69001 | 7.73 | 0.68 | 2.05% | 0.11 |
| D69002 | 7.04 | 0.68 | 2.27% | 0.11 |
| D69003 | 3.59 | 0.68 | 2.92% | 0.07 |
| D69004 | 5.98 | 0.68 | 3.10% | 0.13 |
| D69005 | 4.78 | 0.68 | 3.09% | 0.10 |
| D69006 | 6.80 | 0.68 | 0.32% | 0.01 |
| D69007 | 1.41 | 0.68 | 0.35% | 0.00 |
| D69008 | 7.03 | 0.68 | -0.51% | -0.02 |
| D69009 | 6.09 | 0.68 | -0.03% | 0.00 |
| F03003 | 7.84 | 0.68 | 2.97% | 0.16 |
| F03004 | 3.00 | 0.68 | 1.06% | 0.02 |
| H01190 | 4.36 | 0.68 | 3.40% | 0.10 |
| H01192 | 2.55 | 0.68 | -0.03% | 0.00 |
| H01194 | 3.82 | 0.68 | 3.56% | 0.09 |
| HE3303 | 2.63 | 0.68 | 3.52% | 0.06 |
| HE3304 | 1.43 | 0.68 | 5.58% | 0.05 |
| HE3305 | 0.53 | 0.68 | 2.38% | 0.01 |
| J05138 | 2.28 | 0.68 | 2.92% | 0.05 |
| J05139 | 4.39 | 0.68 | 2.97% | 0.09 |
| J07135 | 5.03 | 0.68 | 3.22% | 0.11 |
| J12166 | 4.54 | 0.68 | 3.90% | 0.12 |
| J13108 | 3.27 | 0.68 | 3.48% | 0.08 |
| J18267 | 5.30 | 0.68 | 3.00% | 0.11 |
| J18268 | 4.68 | 0.68 | 2.62% | 0.08 |
| J47175 | 2.14 | 0.68 | 0.07% | 0.00 |
| J47176 | 3.01 | 0.68 | 3.34% | 0.07 |
| J47178 | 5.99 | 0.68 | 2.65% | 0.11 |
| J47179 | 2.90 | 0.68 | 5.36% | 0.11 |
| J68401 | 5.92 | 0.68 | 1.98% | 0.08 |
| J68402 | 2.30 | 0.68 | 3.78% | 0.06 |
| J82116 | 1.50 | 0.68 | 4.75% | 0.05 |
| J83137 | 3.06 | 0.68 | 3.60% | 0.07 |
| J83139 | 2.53 | 0.68 | 4.19% | 0.07 |
| J86108 | 3.85 | 0.68 | 3.90% | 0.10 |
| J86118 | 4.64 | 0.68 | 3.46% | 0.11 |
| K36151 | 4.05 | 0.68 | 1.30% | 0.04 |

| Circuit | Annual Peak Demand 2014–2016 (MW) | $CVR_{f,PEAK}$ | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|----------------|--|----------------------------|
| K36252 | 1.20 | 0.68 | 3.09% | 0.03 |
| K57211 | 9.55 | 0.68 | 5.24% | 0.34 |
| K57212 | 2.98 | 0.68 | 3.85% | 0.08 |
| K58210 | 6.06 | 0.68 | 3.80% | 0.16 |
| K58213 | 3.51 | 0.68 | 4.40% | 0.11 |
| K71810 | 2.48 | 0.68 | 5.08% | 0.09 |
| K71811 | 3.71 | 0.68 | 4.71% | 0.12 |
| K71812 | 8.02 | 0.68 | 4.06% | 0.22 |
| K71822 | 3.35 | 0.68 | 4.78% | 0.11 |
| K78351 | 4.93 | 0.68 | 4.48% | 0.15 |
| K78352 | 3.67 | 0.68 | 4.56% | 0.11 |
| K82202 | 4.80 | 0.68 | 1.78% | 0.06 |
| L08225 | 1.81 | 0.68 | 2.04% | 0.03 |
| L11241 | 1.79 | 0.68 | 3.92% | 0.05 |
| L11244 | 2.15 | 0.68 | 3.99% | 0.06 |
| L14231 | 2.79 | 0.68 | 2.37% | 0.04 |
| L50217 | 2.77 | 0.68 | 3.23% | 0.06 |
| L71170 | 2.82 | 0.68 | 4.34% | 0.08 |
| L73154 | 1.58 | 0.68 | 3.40% | 0.04 |
| L73155 | 1.27 | 0.68 | 3.42% | 0.03 |
| L73156 | 1.20 | 0.68 | 3.94% | 0.03 |
| L73184 | 0.78 | 0.68 | 3.63% | 0.02 |
| L73185 | 1.80 | 0.68 | 1.75% | 0.02 |
| M05360 | 5.47 | 0.68 | 3.58% | 0.13 |
| M05361 | 4.34 | 0.68 | 3.57% | 0.11 |
| M05362 | 5.62 | 0.68 | 3.48% | 0.13 |
| M54314 | 1.49 | 0.68 | 4.43% | 0.04 |
| M54316 | 1.53 | 0.68 | 4.36% | 0.05 |
| M54317 | 1.54 | 0.68 | 3.19% | 0.03 |
| M73329 | 2.07 | 0.68 | 3.07% | 0.04 |
| M73330 | 1.77 | 0.68 | 4.07% | 0.05 |
| N14879 | 2.43 | 0.68 | 4.09% | 0.07 |
| N14880 | 2.21 | 0.68 | 3.61% | 0.05 |
| N73121 | 1.57 | 0.68 | 3.34% | 0.04 |
| P53341 | 3.65 | 0.68 | 2.55% | 0.06 |
| P77235 | 3.01 | 0.68 | 3.62% | 0.07 |
| P77237 | 2.17 | 0.68 | 4.44% | 0.07 |
| Q10702 | 5.05 | 0.68 | 4.67% | 0.16 |
| Q18243 | 2.60 | 0.68 | 3.95% | 0.07 |
| Q18244 | 4.91 | 0.68 | 4.22% | 0.14 |
| Q18245 | 4.48 | 0.68 | 4.33% | 0.13 |
| Q21292 | 4.88 | 0.68 | 3.46% | 0.11 |
| Q21293 | 4.33 | 0.68 | 5.15% | 0.15 |

| Circuit | Annual Peak Demand 2014–2016 (MW) | $CVR_{f,PEAK}$ | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|----------------|--|----------------------------|
| Q21294 | 6.10 | 0.68 | 3.84% | 0.16 |
| Q21321 | 4.44 | 0.68 | 3.09% | 0.09 |
| Q21322 | 1.95 | 0.68 | 2.72% | 0.04 |
| Q21423 | 8.06 | 0.68 | 3.24% | 0.18 |
| Q24310 | 4.77 | 0.68 | 5.28% | 0.17 |
| Q24311 | 4.30 | 0.68 | 5.28% | 0.15 |
| Q24312 | 3.57 | 0.68 | 5.32% | 0.13 |
| Q67948 | 1.74 | 0.68 | 4.55% | 0.05 |
| R01152 | 3.97 | 0.68 | 2.24% | 0.06 |
| R10941 | 0.50 | 0.68 | 4.72% | 0.02 |
| R10943 | 2.34 | 0.68 | 2.92% | 0.05 |
| R50910 | 5.41 | 0.68 | 2.66% | 0.10 |
| R58921 | 1.72 | 0.68 | 4.07% | 0.05 |
| R66472 | 3.02 | 0.68 | 4.10% | 0.08 |
| R71286 | 2.82 | 0.68 | 4.35% | 0.08 |
| R93350 | 3.37 | 0.68 | 3.56% | 0.08 |
| R93351 | 3.53 | 0.68 | 4.64% | 0.11 |
| R95520 | 2.43 | 0.68 | 2.84% | 0.05 |
| S01511 | 2.02 | 0.68 | 2.95% | 0.04 |
| S01521 | 2.21 | 0.68 | 2.54% | 0.04 |
| S01558 | 0.67 | 0.68 | 4.41% | 0.02 |
| S13548 | 1.60 | 0.68 | 2.37% | 0.03 |
| S13550 | 1.07 | 0.68 | 5.12% | 0.04 |
| S20554 | 0.77 | 0.68 | 1.79% | 0.01 |
| S47537 | 3.22 | 0.68 | 4.59% | 0.10 |
| S47575 | 3.55 | 0.68 | 3.74% | 0.09 |
| S47576 | 3.37 | 0.68 | 2.10% | 0.05 |
| S47586 | 2.13 | 0.68 | 3.17% | 0.05 |
| U07001 | 1.40 | 0.68 | 3.57% | 0.03 |
| U07002 | 1.39 | 0.68 | 3.39% | 0.03 |
| U09540 | 3.03 | 0.68 | 4.37% | 0.09 |
| U09557 | 6.00 | 0.68 | 3.76% | 0.15 |
| U09569 | 2.00 | 0.68 | 3.57% | 0.05 |
| U57560 | 2.89 | 0.68 | 3.49% | 0.07 |
| U57561 | 1.81 | 0.68 | 3.15% | 0.04 |
| U60518 | 3.86 | 0.68 | 1.41% | 0.04 |
| U64518 | 0.86 | 0.68 | 4.18% | 0.02 |
| U64521 | 3.08 | 0.68 | 4.23% | 0.09 |
| U80003 | 1.83 | 0.68 | 2.62% | 0.03 |
| U80564 | 3.80 | 0.68 | 2.70% | 0.07 |
| V04537 | 1.40 | 0.68 | 3.96% | 0.04 |
| V21500 | 3.88 | 0.68 | 2.50% | 0.07 |
| V21548 | 1.39 | 0.68 | 4.83% | 0.05 |

| Circuit | Annual Peak Demand 2014–2016 (MW) | $CVR_{f,PEAK}$ | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|----------------|--|----------------------------|
| V38001 | 1.47 | 0.68 | 4.33% | 0.04 |
| V38003 | 0.91 | 0.68 | 3.16% | 0.02 |
| V40549 | 2.05 | 0.68 | 2.13% | 0.03 |
| V41527 | 2.86 | 0.68 | 3.83% | 0.07 |
| V43543 | 2.33 | 0.68 | 2.13% | 0.03 |
| V43565 | 3.51 | 0.68 | 0.90% | 0.02 |
| V47001 | 2.13 | 0.68 | 4.26% | 0.06 |
| V55524 | 2.11 | 0.68 | 3.67% | 0.05 |
| V89523 | 1.53 | 0.68 | 3.64% | 0.04 |
| V92542 | 2.43 | 0.68 | 3.53% | 0.06 |
| V92543 | 2.70 | 0.68 | 3.44% | 0.06 |
| V92555 | 2.76 | 0.68 | 2.63% | 0.05 |
| X19561 | 3.22 | 0.68 | 2.78% | 0.06 |
| X35500 | 0.80 | 0.68 | 4.86% | 0.03 |
| X35564 | 1.30 | 0.68 | 4.05% | 0.04 |
| X64002 | 0.89 | 0.68 | 3.44% | 0.02 |
| X64003 | 1.27 | 0.68 | 4.30% | 0.04 |
| X64503 | 2.65 | 0.68 | 2.79% | 0.05 |
| X66581 | 2.81 | 0.68 | 4.45% | 0.09 |
| X82576 | 1.48 | 0.68 | 2.92% | 0.03 |
| X82585 | 1.74 | 0.68 | 2.87% | 0.03 |
| X83533 | 2.26 | 0.68 | 3.88% | 0.06 |
| X96001 | 1.47 | 0.68 | 3.29% | 0.03 |
| X96002 | 0.93 | 0.68 | 4.16% | 0.03 |
| X96523 | 2.00 | 0.68 | 3.28% | 0.04 |
| Y11555 | 2.73 | 0.68 | 3.09% | 0.06 |
| Y11557 | 3.97 | 0.68 | 3.93% | 0.11 |
| Y31589 | 2.23 | 0.68 | 1.11% | 0.02 |
| Y31591 | 1.02 | 0.68 | 4.11% | 0.03 |
| Y32571 | 1.50 | 0.68 | 3.30% | 0.03 |
| Y32572 | 1.43 | 0.68 | 3.70% | 0.04 |
| Y36541 | 2.25 | 0.68 | 3.77% | 0.06 |
| Y54001 | 0.84 | 0.68 | 3.37% | 0.02 |
| Y54560 | 4.19 | 0.68 | 3.02% | 0.09 |
| Y54587 | 3.90 | 0.68 | 2.43% | 0.06 |
| Y54591 | 1.63 | 0.68 | 3.19% | 0.04 |
| Y66556 | 2.15 | 0.68 | 3.06% | 0.04 |
| Y69553 | 1.21 | 0.68 | 4.17% | 0.03 |
| Y69565 | 1.53 | 0.68 | 3.34% | 0.03 |
| Y86593 | 2.10 | 0.68 | 2.32% | 0.03 |
| Y86595 | 3.31 | 0.68 | 0.22% | 0.01 |
| Y98518 | 3.49 | 0.68 | 4.08% | 0.10 |
| Y98561 | 2.26 | 0.68 | 3.35% | 0.05 |

| Circuit | Annual Peak Demand 2014–2016 (MW) | $CVR_{f,PEAK}$ | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|----------------|--|----------------------------|
| Z06538 | 2.98 | 0.68 | 3.45% | 0.07 |
| Z08509 | 3.34 | 0.68 | 2.43% | 0.06 |
| Z11536 | 2.44 | 0.68 | 3.11% | 0.05 |
| Z19532 | 2.14 | 0.68 | 5.43% | 0.08 |
| Z33511 | 4.80 | 0.68 | 3.07% | 0.10 |
| Z51556 | 2.97 | 0.68 | 4.56% | 0.09 |
| V92542 | 2.43 | 0.68 | 3.53% | 0.06 |
| V92543 | 2.70 | 0.68 | 3.44% | 0.06 |
| V92555 | 2.76 | 0.68 | 2.63% | 0.05 |
| X19561 | 3.22 | 0.68 | 2.78% | 0.06 |
| X35500 | 0.80 | 0.68 | 4.86% | 0.03 |
| X35564 | 1.30 | 0.68 | 4.05% | 0.04 |
| X64002 | 0.89 | 0.68 | 3.44% | 0.02 |
| X64003 | 1.27 | 0.68 | 4.30% | 0.04 |
| X64503 | 2.65 | 0.68 | 2.79% | 0.05 |
| X66581 | 2.81 | 0.68 | 4.45% | 0.09 |
| X82576 | 1.48 | 0.68 | 2.92% | 0.03 |
| X82585 | 1.74 | 0.68 | 2.87% | 0.03 |
| X83533 | 2.26 | 0.68 | 3.88% | 0.06 |
| X96001 | 1.47 | 0.68 | 3.29% | 0.03 |
| X96002 | 0.93 | 0.68 | 4.16% | 0.03 |
| X96523 | 2.00 | 0.68 | 3.28% | 0.04 |
| Y11555 | 2.73 | 0.68 | 3.09% | 0.06 |
| Y11557 | 3.97 | 0.68 | 3.93% | 0.11 |
| Y31589 | 2.23 | 0.68 | 1.11% | 0.02 |
| Y31591 | 1.02 | 0.68 | 4.11% | 0.03 |
| Y32571 | 1.50 | 0.68 | 3.30% | 0.03 |
| Y32572 | 1.43 | 0.68 | 3.70% | 0.04 |
| Y36541 | 2.25 | 0.68 | 3.77% | 0.06 |
| Y54001 | 0.84 | 0.68 | 3.37% | 0.02 |
| Y54560 | 4.19 | 0.68 | 3.02% | 0.09 |
| Y54587 | 3.90 | 0.68 | 2.43% | 0.06 |
| Y54591 | 1.63 | 0.68 | 3.19% | 0.04 |
| Y66556 | 2.15 | 0.68 | 3.06% | 0.04 |
| Y69553 | 1.21 | 0.68 | 4.17% | 0.03 |
| Y69565 | 1.53 | 0.68 | 3.34% | 0.03 |
| Y86593 | 2.10 | 0.68 | 2.32% | 0.03 |
| Y86595 | 3.31 | 0.68 | 0.22% | 0.01 |
| Y98518 | 3.49 | 0.68 | 4.08% | 0.10 |
| Y98561 | 2.26 | 0.68 | 3.35% | 0.05 |
| Z06538 | 2.98 | 0.68 | 3.45% | 0.07 |
| Z08509 | 3.34 | 0.68 | 2.43% | 0.06 |
| Z11536 | 2.44 | 0.68 | 3.11% | 0.05 |

| Circuit | Annual Peak Demand 2014–2016 (MW) | $CVR_{f,PEAK}$ | Average Percent Change in Peak Voltage | Annual Demand Savings (MW) |
|---------|-----------------------------------|----------------|--|----------------------------|
| Z19532 | 2.14 | 0.68 | 5.43% | 0.08 |
| Z33511 | 4.80 | 0.68 | 3.07% | 0.10 |
| Z51556 | 2.97 | 0.68 | 4.56% | 0.09 |

APPENDIX C. CUMULATIVE PERSISTING ANNUAL SAVINGS

Table 13 provides CPAS and WAML for the 2024 VO Program through 2039. Lifetime savings for the 2024 VO Program are 1,157,529 MWh.

Table 13. 2024 VO Program CPAS and WAML through 2039

| Measure Category | Measure Life | Annual Verified Gross Savings (MWh) | NTGR | CPAS - Verified Net Savings (MWh) | | | | | | | |
|------------------------------------|--------------|-------------------------------------|-------|-----------------------------------|--------|--------|--------|--------|--------|--------|--------|
| | | | | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 |
| Voltage Optimization - 2024 Cohort | 15.0 | 77,169 | 1.000 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 |
| 2024 CPAS | | 77,169 | N/A | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 |
| Expiring 2024 CPAS | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Expired 2024 CPAS | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

| Measure Category | Measure Life | Annual Verified Gross Savings (MWh) | NTGR | CPAS - Verified Net Savings (MWh) | | | | | | | |
|------------------------------------|--------------|-------------------------------------|-------|-----------------------------------|--------|--------|--------|--------|--------|--------|--------|
| | | | | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 |
| Voltage Optimization - 2024 Cohort | 15.0 | 77,169 | 1.000 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 0 |
| 2024 CPAS | | 77,169 | N/A | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 77,169 | 0 |
| Expiring 2024 CPAS | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 77,169 |
| Expired 2024 CPAS | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 77,169 |
| WAML | 15.0 | | | | | | | | | | |

Table 14 presents cumulative verified CPAS and expected CPAS per the original AIC VO plan. As of the end of program year 2024, cumulative verified CPAS exceeded the expected CPAS by 22%.

Table 14. Total CPAS vs. Expected CPAS Per AIC's Original VO Implementation Plan

| Year Ending | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|--|------|-------|--------|---------|---------|---------|---------|---------|
| Expected Cumulative Persisting Annual Savings (MWh) per AIC's VO Implementation Plan | 0 | 7,650 | 59,994 | 128,433 | 201,725 | 275,006 | 348,287 | 421,568 |
| Total Cumulative Persisting Annual Savings (MWh) ^a | 0 | 9,175 | 81,843 | 177,275 | 264,167 | 347,583 | 424,751 | N/A |
| % of Expected Savings Reached by End of Evaluation Period | N/A | 120% | 136% | 138% | 131% | 126% | 122% | N/A |

^a This row contains the total CPAS from all years of VO Program implementation (2019–2024) and, therefore, differs from the values presented in Table 13 above, which presents only CPAS from the 2024 VO Program.

APPENDIX D. VERIFICATION OF CONTINUED OPERATIONS

Opinion Dynamics conducted an analysis of the 2019, 2020, 2021, 2022, and 2023 cohorts of circuits to verify continued operations. Since VO savings are deemed for 15 years after completion of the initial evaluation of a circuit, and no retroactive changes are subsequently made to the savings, verification is necessary to confirm continued operation.

In 2020, Opinion Dynamics, AIC, and ICC Staff agreed that ongoing verification of VO should be conducted to provide information to all stakeholders about the level of continued VO operation and, if needed, to provide context as to why VO may not have operated continuously. After the initial evaluation of each year of circuits, all parties agreed that Opinion Dynamics would conduct verification activities to assess the degree to which VO continued to operate throughout each year. The acceptable uptime threshold of operation was set to ensure that circuits operated over a 90% threshold.²²

The purpose of this verification is to provide information to stakeholders and other parties as to the level of continued operation of VO throughout the deemed 15-year period of savings and, if needed, to provide context as to why VO may not have operated continuously at the acceptable 90% uptime threshold throughout the period.

We conducted the following activities to determine whether these circuits operated over a 90% uptime threshold.

- **Sample Selection.** We randomly selected roughly 10% of each of the previously evaluated cohorts of circuits. This translates to 2 of the 19 circuits evaluated in 2019, 13 of the 125 circuits evaluated in 2020, 18 of the 180 circuits evaluated in 2021, 19 of the 181 circuits evaluated in 2022, and 20 of the 194 circuits. See Table 15 for the list of sampled circuits. Sample selection was performed retrospectively and provided to AIC in the second half of December of the evaluation year. This was done to ensure that the anticipated evaluation did not change the operations of the circuits subject to verification of continued operation.
- **Review operation log summaries for the sample.** The variable of interest for this effort included the VO status (i.e., VO “On” and VO “Off”) for specific hours throughout the year at a circuit level. We were able to rely on the VO status log summaries for this analysis since we generally expected VO to run for nearly all hours in a year.
- **Data cleaning.** Opinion Dynamics did not perform any data cleaning prior to the verification activities except for removing excludable events. Excludable events are discussed in detail in Appendix B.
- **Calculated operation status.** We calculated the proportion of hours that each circuit’s VO status was “On” for a given year. We then divided the total number of hours the status logs indicated that VO was operational by the total number of non-excludable hours in the year.

Table 15 presents the sample of the circuits evaluated as part of the 2019, 2020, 2021, 2022, and 2023 circuit verification.

Table 15. Sample of Circuits Evaluated in 2019, 2020, 2021, 2022, and 2023

| Feeder | Substation | Year Previously Evaluated | Uptime (% of 2024)* |
|--------|---------------------------|---------------------------|---------------------|
| C52002 | RIDGE C52002 | 2019 | 99.8% |
| P58155 | MT VERNON 27TH ST P58155 | 2019 | 99.8% |
| P57103 | MT VERNON 11TH ST P57LTC1 | 2020 | 99.8% |
| L93134 | EAST BELLEVILLE L93134 | 2020 | 99.8% |

²² See Ameren Illinois Company Voltage Optimization Verification and Exclusion Approach Memorandum here: <https://www.ilsag.info/wp-content/uploads/AIC-2019-Voltage-Optimization-Operation-Verification-Memo-FINAL-2020-04-17.pdf>

| Feeder | Substation | Year Previously Evaluated | Uptime (% of 2024)* |
|--------|--------------------------------|---------------------------|---------------------|
| K52401 | COLLINSVILLE REESE DR K52401 | 2020 | 99.8% |
| K39154 | CLINTON RT 54 K39154 | 2020 | 99.8% |
| K76546 | CHAMPAIGN OAK ST K76546 | 2020 | 99.5% |
| T06503 | WEST FRANKFORT T06503 | 2020 | 99.8% |
| K52400 | COLLINSVILLE REESE DR K52400 | 2020 | 99.8% |
| L73160 | DANVILLE FRANKLIN ST L73160 | 2020 | 99.8% |
| L12126 | DECATUR MOUND RD L12126 | 2020 | 99.8% |
| B80003 | SHERIDAN B80LTC1 | 2020 | 99.8% |
| N95823 | LITCHFIELD N95823 | 2020 | 95.4% |
| K76545 | CHAMPAIGN OAK ST K76545 | 2020 | 99.8% |
| Y55003 | PAXTON Y55003 | 2020 | 99.8% |
| A17021 | BARTONVILLE A17021 | 2021 | 99.8% |
| P98190 | NORMAL MAIN ST P98190 | 2021 | 99.8% |
| Q01282 | NORMAL RTE 66 Q01282 | 2021 | 99.5% |
| Q28141 | OLD SHAWNEETOWN Q28141 | 2021 | 99.8% |
| N54108 | JACKSONVILLE WEST SIDE N54108 | 2021 | 99.8% |
| L50215 | DUPO L50215 | 2021 | 99.8% |
| X60595 | EFFINGHAM N X60595 | 2021 | 99.8% |
| L50214 | DUPO L50214 | 2021 | 99.8% |
| 349002 | SUMMIT 349 | 2021 | 99.8% |
| A97004 | EAST PEORIA PARALLEL A97LTC | 2021 | 99.8% |
| R59417 | URBANA GOODWIN R59417 | 2021 | 99.8% |
| R48167 | TILTON ROSS LANE R48167 | 2021 | 99.8% |
| X77543 | GILMAN S X77543 | 2021 | 99.8% |
| U33509 | CANTON SPOON RIVER U33509 | 2021 | 99.5% |
| C40001 | HAUK C40LTC1 | 2021 | 99.8% |
| P98193 | NORMAL MAIN ST P98193 | 2021 | 99.8% |
| Q80352 | ROSEWOOD HEIGHTS Q80352 | 2021 | 99.8% |
| J63173 | BLOOMINGTON PROSPECT J63173 | 2021 | 99.8% |
| Q23256 | OFALLON SEVEN HILLS ROAD | 2022 | 99.8% |
| P20930 | MARISSA P20930 | 2022 | 99.8% |
| M40132 | GALESBURG MONMOUTH BLVD M40132 | 2022 | 99.8% |
| C37001 | BISSELL C37001 | 2022 | 99.8% |
| R28870 | STAUNTON SPRING STREET R28870 | 2022 | 93.2% |
| B45005 | GRANDVIEW PARALLEL B45LTC | 2022 | 99.8% |
| Z41528 | TEUTOPOLIS WEST Z41528 | 2022 | 99.8% |
| M40117 | GALESBURG MONMOUTH BLVD M40117 | 2022 | 99.8% |
| K73362 | CHAMPAIGN LEVERETT RD K73362 | 2022 | 99.8% |
| S61531 | MARION S61531 | 2022 | 99.8% |
| J50186 | BLOOMINGTON GE ROAD J50186 | 2022 | 99.8% |
| D96001 | SALEM D96001 | 2022 | 99.8% |
| N67309 | KEWANEE NORTH MAIN ST N67309 | 2022 | 99.8% |
| A36002 | EUREKA A36002 | 2022 | 99.8% |

| Feeder | Substation | Year Previously Evaluated | Uptime (% of 2024)* |
|--------|-----------------------------------|---------------------------|---------------------|
| R41131 | TEXAS R41131 | 2022 | 99.8% |
| K09864 | CARLINVILLE K09864 | 2022 | 99.8% |
| R49275 | TRENTON R49275 | 2022 | 99.8% |
| K09863 | CARLINVILLE K09863 | 2022 | 99.8% |
| L74194 | DANVILLE HAZEL ST L74194 | 2022 | 99.8% |
| B21001 | FONDULAC B21LTC1 | 2023 | 99.8% |
| B76001 | KICE B76001 | 2023 | 99.8% |
| P85141 | NORMAL P85141 | 2023 | 99.8% |
| S49550 | HERRIN SW S49550 | 2023 | 99.8% |
| M49424 | GLEN CARBON MAIN ST M49424 | 2023 | 99.8% |
| J88162 | BELLEVILLE BELLE VALLEY J88162 | 2023 | 99.8% |
| P49183 | MONMOUTH HARLEM AVE P49183 | 2023 | 99.8% |
| HK8115 | DECATUR OLIVE STREET HK8LTC1 | 2023 | 99.8% |
| B28006 | KOCH B28LTC1 | 2023 | 99.8% |
| D53001 | MINDALE 69KV D53001 | 2023 | 99.5% |
| G50002 | BEMENT G50 | 2023 | 99.8% |
| B27008 | ADAMS B27LTC2 | 2023 | 99.8% |
| S43511 | HARRISBURG S S43511 | 2023 | 99.8% |
| L80221 | DANVILLE LYNCH ROAD L80221 | 2023 | 94.3% |
| P85146 | NORMAL P85146 | 2023 | 99.8% |
| B93001 | FULTON B93001 | 2023 | 97.1% |
| T23527 | GOREVILLE N T23527 | 2023 | 99.8% |
| Y63531 | ROBINSON E Y63531 | 2023 | 99.8% |
| S19556 | CARBONDALE UNIVERSITY MALL S19556 | 2023 | 94.7% |
| Z18554 | PARIS INDUSTRIAL PARK Z18554 | 2023 | 99.8% |

^a Excludes excludable events



Opinion **Dynamics**

CONTACT:

Zach Ross

Director

zross@opiniondynamics.com

Shihab Siddiqui, Ph.D.

Principal Consultant

ssiddiqui@opiniondynamics.com



BOSTON

PORTLAND

SAN DIEGO

SAN FRANCISCO