

Nicor Gas Energy Efficiency Program - Plan Year 2023

Quarterly Report: First Quarter (January 1, 2023 - March 31, 2023)

Response to Evaluators' Recommendations

APPENDIX B

Program	PY	Recommendation	Action Completion Date	Action(s) Taken
Business Energy Efficiency Rebates	2021	Measure: Boiler Tune-Ups Ensure reported savings input values are properly recorded in the respective fields in the tracking data.	1/30/2023	Nicor Gas implemented additional QA/QC checks to ensure reported savings input values are properly recorded in the respective fields in the tracking data
Business Energy Efficiency Rebates	2021	Measure: Water Heaters Ensure the tracking data provides explanation behind any reclassifications between mid-year and final datasets.	1/30/2023	Nicor Gas implemented additional QA/QC checks to ensure accurate measure descriptions are tracked in the datasets.
MF CPOP	2021	Measure: Boiler Reset Controls Review the database entries for these two projects and ensure that future calculations for this measure include additional quality assurance checks in the tracking system.	1/30/2023	Nicor Gas implemented additional QA/QC checks to ensure accurate therm savings are being reported in tracking data
MF Prescriptive	2021	Measure: Condensing Boilers Use a baseline boiler efficiency of 80% for condensing boilers with capacity greater than 300 MBH and less than 2,500 MBH per the IL TRM v9.0 Section 4.4.10.	1/30/2023	Nicor Gas implemented additional QA/QC checks to ensure the correct TRM algorithm is used