

Ameren Illinois On-Bill Financing Measures

Considering the limitations of the statutory payback formula, we found the best approach was to determine the tipping point of what baseline efficiency was needed to make the measure pass.

1) Insulation;

Roof: Replacing R11 or lower with R38 or higher.

Wall: Replacing empty or R0 with R11 or greater.

2) Air Sealing; Achieve 30% reduction

3) Air Source Heat Pump; Replacing SEER 10 or lower with a SEER 14 or higher.

4) Central AC; Replacing SEER 8 or lower with a SEER 14 or higher.

5) Furnaces; Replacing AFUE 75% with 95% or higher.

6) Heat Pump Water Heater; Replacing electric water heater at 90% efficiency or lower with a water heater with an EF greater than 2.0

7) Moderate Income;

This is a program for households at 200%-300% of poverty where our higher incentives and a grant program pay for the balance of the retrofit.

Dependent on customer contribution:

<u>Contribution</u>	<u>Minimum Installed Measure(s)</u>
\$500	Any measure
\$1,000	Any one measure, other than Gas Water Heater
\$2,000	Any two measures (one of the two can include Gas Water Heater)