

# Report by FSTC - case study tankless -

1. 125 MBH, 60 gal  $E_t = 95\%$   $SL = 500 \text{ Btu/h}$
2. Std eff 236 MBH Tankless  $E_t = 82\%$  <sup>cat'd</sup> using mfr's input rate & capacity specs)
3. HE 199 MBH tankless  $91.7\% = E_t$  from mfr's Spec Sht

FSTC recommended

$T_{in}$  Restaurant use either the  
 $T_{out}$  tank or the tankless  
 $GPM$  (95% vs 92% eff - little diff)  
 $NG$  consumption

usage 500 g/d 200 - 900 /d over month

10 gpm peak flow tank htr.

Inherent in its design, at full capacity, a tankless htr typ. will restrict flow of htr to maintain a constant setpt outlet T

$SD: 5 \text{ gpm}$  ; Since not connected to flow sensitive equip (dishwasher) <sup>usage</sup> OK

# 221 (21.20 / therm) Savings the tank over std eff tankless

# 72 / yr savings using the tank over the tankless  
 the tankless save \$149 / yr over std <sup>eff</sup> tankless